



**Ministry of Health and
Long-Term Care**

**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Ministère de la Santé et des
Soins de longue durée**

**Rapport d'inspection
prévus le Loi de 2007 les
foyers de soins de longue**

Health System Accountability and Performance
Division

Performance Improvement and Compliance Branch

Division de la responsabilisation et de la
performance du système de santé

Direction de l'amélioration de la performance et de la
conformité

Ottawa Service Area Office

347 Preston St, 4th Floor

OTTAWA, ON, K1S-3J4

Telephone: (613) 569-5602

Facsimile: (613) 569-9670

Bureau régional de services d'Ottawa

347, rue Preston, 4^{ième} étage

OTTAWA, ON, K1S-3J4

Téléphone: (613) 569-5602

Télécopieur: (613) 569-9670

Public Copy/Copie du public

Date(s) of inspection/Date(s) de l'inspection	Inspection No/ No de l'inspection	Type of Inspection/Genre d'inspection
Jan 23, 24, 2012	2012_054133_0001	Complaint

Licensee/Titulaire de permis

THE CORPORATION OF THE COUNTY OF LANARK
P.O. Box 37, Sunset Blvd., PERTH, ON, K7H-3E2

Long-Term Care Home/Foyer de soins de longue durée

LANARK LODGE
115 Christie Lake Road, R. R. #4, Lot 27, Concession 2, PERTH, ON, K7H-3C6

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

JESSICA LAPENSEE (133)

Inspection Summary/Résumé de l'inspection

The purpose of this inspection was to conduct a Complaint inspection.

During the course of the inspection, the inspector(s) spoke with the Administrator, the Environmental Services Manager, a Registered Nurse, Registered Practical Nurses, Personal Support Workers and residents

During the course of the inspection, the inspector(s) verified the temperature of the hot water at each bathtub in the home, reviewed the documented "Unit Hot Water Temperature Log" for November 2011 and December 2011 and reviewed the documented "Hot Water Temperature Checks A-Wing Boiler Room" for Oct 30th 2011 to January 13th 2012. The inspector also reviewed a "General Notice" from the Administrator to all Lanark Lodge residents, families and staff dated November 30th 2011 on the subject of the hot water tank for the resident bathing system.

The following Inspection Protocols were used during this inspection:
Accommodation Services - Maintenance

There are no findings of Non-Compliance as a result of this inspection.

NON-COMPLIANCE / NON-RESPECT DES EXIGENCES



**Ministry of Health and
Long-Term Care**

**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Ministère de la Santé et des
Soins de longue durée**

**Rapport d'inspection
prévus le Loi de 2007 les
foyers de soins de longue**

Legend	Legendé
WN – Written Notification VPC – Voluntary Plan of Correction DR – Director Referral CO – Compliance Order WAO – Work and Activity Order	WN – Avis écrit VPC – Plan de redressement volontaire DR – Aiguillage au directeur CO – Ordre de conformité WAO – Ordres : travaux et activités
Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.) The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.	Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD. Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.

Issued on this 24th day of January, 2012

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

Jessica Lapensée