



**Ministry of Health and
Long-Term Care**

**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Ministère de la Santé et des
Soins de longue durée**

**Rapport d'inspection sous la
Loi de 2007 sur les foyers de
soins de longue durée**

**Health System Accountability and
Performance Division
Performance Improvement and
Compliance Branch**

**Division de la responsabilisation et de la
performance du système de santé
Direction de l'amélioration de la
performance et de la conformité**

**Hamilton Service Area Office
119 King Street West, 11th Floor
HAMILTON, ON, L8P-4Y7
Telephone: (905) 546-8294
Facsimile: (905) 546-8255**

**Bureau régional de services de
Hamilton
119, rue King Ouest, 11^{ème} étage
HAMILTON, ON, L8P-4Y7
Téléphone: (905) 546-8294
Télécopieur: (905) 546-8255**

Public Copy/Copie du public

Report Date(s) / Date(s) du Rapport	Inspection No / No de l'inspection	Log # / Registre no	Type of Inspection / Genre d'inspection
Aug 13, 2013	2013_189120_0053	H-000481- 13	Critical Incident System

Licensee/Titulaire de permis

**VIGOUR LIMITED PARTNERSHIP ON BEHALF OF VIGOUR
302 Town Centre Blvd, Suite #200, MARKHAM, ON, L3R-0E8**

Long-Term Care Home/Foyer de soins de longue durée

**LEISUREWORLD CAREGIVING CENTRE - MISSISSAUGA
2250 HURONTARIO STREET, MISSISSAUGA, ON, L5B-1M8**

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

BERNADETTE SUSNIK (120)

Inspection Summary/Résumé de l'inspection

The purpose of this inspection was to conduct a Critical Incident System inspection.

This inspection was conducted on the following date(s): August 9, 2013

During the course of the inspection, the inspector(s) spoke with the administrator, environmental services supervisor and the director of care regarding a power failure between July 8 and July 9, 2013.

During the course of the inspection, the inspector(s) reviewed the home's power loss and essential services contingency plans.

The following Inspection Protocols were used during this inspection:



Safe and Secure Home

Findings of Non-Compliance were found during this inspection.

NON-COMPLIANCE / NON - RESPECT DES EXIGENCES	
Legend	Legendé
WN – Written Notification	WN – Avis écrit
VPC – Voluntary Plan of Correction	VPC – Plan de redressement volontaire
DR – Director Referral	DR – Aiguillage au directeur
CO – Compliance Order	CO – Ordre de conformité
WAO – Work and Activity Order	WAO – Ordres : travaux et activités
Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)	Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.
The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.	Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.

WN #1: The Licensee has failed to comply with O.Reg 79/10, s. 19. Generators Specifically failed to comply with the following:

s. 19. (4) The licensee of a home to which subsection (2) or (3) applies shall ensure, not later than six months after the day this section comes into force, that the home has guaranteed access to a generator that will be operational within three hours of a power outage and that can maintain everything required under clauses (1) (a), (b) and (c). O. Reg. 79/10, s. 19 (4).

Findings/Faits saillants :



The licensee did not have guaranteed access to a generator that was operational within 3 hours of a power outage and that could maintain the heating system, dietary services equipment (fridges, freezers, steam tables, food processing equipment), elevators and life support equipment (oxygen concentrators, enteral feeding systems, dialysis machines, therapeutic surfaces etc.).

The City of Mississauga, where the home is situated, was affected by a wide area power outage due to a storm beginning at approximately 5:30 p.m. July 8, 2013. The home was without power to operate their heating system (if necessary), dietary services equipment, elevators and life support equipment between 6:00 p.m. July 8, 2013 until 4:00 a.m. July 9, 2013. Approximately 40 residents who were having their dinner meal in the home's main floor dining room became stranded in the dining room between 6:15 p.m. and the following morning. The home's elevators could not be used to transport residents back to their rooms and for those who could not use the stairs, no alternative method of transport was available. Residents were accommodated on their own mattresses within the dining room.

The home's cold holding equipment was not supplied with any back up power and all perishable foods had to be discarded the following morning. None of the meals however were affected and residents received their planned menu items.

The home was able to provide some services (telecommunications, fire alarms, fire panel, partial emergency lighting, door security system, resident-staff communication and response system) over the course of the power outage by using a portable generator.

The administrator provided information that they have a contract with a generator rental agency, however the administrator did not proceed with initiating the delivery of a generator due to the unpredictability of the power outage. [s. 19(4)]

Additional Required Actions:

CO # - 001 will be served on the licensee. Refer to the "Order(s) of the Inspector".

WN #2: The Licensee has failed to comply with O.Reg 79/10, s. 230. Emergency plans



Specifically failed to comply with the following:

s. 230. (4) The licensee shall ensure that the emergency plans provide for the following:

- 1. Dealing with,**
 - i. fires,**
 - ii. community disasters,**
 - iii. violent outbursts,**
 - iv. bomb threats,**
 - v. medical emergencies,**
 - vi. chemical spills,**
 - vii. situations involving a missing resident, and**
 - viii. loss of one or more essential services. O. Reg. 79/10, s. 230 (4).**
-

s. 230. (5) The licensee shall ensure that the emergency plans address the following components:

- 1. Plan activation. O. Reg. 79/10, s. 230 (5).**
 - 2. Lines of authority. O. Reg. 79/10, s. 230 (5).**
 - 3. Communications plan. O. Reg. 79/10, s. 230 (5).**
 - 4. Specific staff roles and responsibilities. O. Reg. 79/10, s. 230 (5).**
-

Findings/Faits saillants :



The home's emergency plans did not provide for dealing with loss of one or more essential services such as elevators.

The home has 2 elevators, 4 floors, 237 residents and over 50 staff. The elevators are heavily used to transport residents from the various floors down to the main floor dining room, 3 times per day. More than 80% of the residents are dependent on a wheelchair or walker and are not able to use the stairs. During the power outage beginning on July 8, 2013, the elevators were not functional and approximately 40 residents became stranded on the main floor and had to spend the night in the dining room. Residents on the other floors were also stranded in that they could not leave their floor if necessary. The home did not have any contingency plans to address how residents, supplies, equipment, linens and foods would be transported within the home when elevators are not functioning either due to mechanical reasons or due to a power loss. [s. 230(4)1]

2. The home's emergency plans did not address the following components:

1. Plan activation
2. Lines of authority
3. Communications plan.

The home's emergency plans for loss of hydro provides specific staff roles and responsibilities but the other components are missing or very vague. The plan has not been customized for the home and it's specific unique challenges. [s. 230(5)]



Ministry of Health and
Long-Term Care

Ministère de la Santé et des
Soins de longue durée

Inspection Report under
the Long-Term Care
Homes Act, 2007

Rapport d'inspection sous la
Loi de 2007 sur les foyers de
soins de longue durée

Issued on this 13th day of August, 2013

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

B. Sosnik



Ministry of Health and
Long-Term Care

Ministère de la Santé et
des Soins de longue durée

Order(s) of the Inspector
Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

Ordre(s) de l'inspecteur
Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

Health System Accountability and Performance Division
Performance Improvement and Compliance Branch

Division de la responsabilisation et de la performance du système de santé
Direction de l'amélioration de la performance et de la conformité

Public Copy/Copie du public

Name of Inspector (ID #) /

Nom de l'inspecteur (No) : BERNADETTE SUSNIK (120)

Inspection No. /

No de l'inspection : 2013_189120_0053

Log No. /

Registre no: H-000481-13

Type of Inspection /

Genre d'inspection: Critical Incident System

Report Date(s) /

Date(s) du Rapport : Aug 13, 2013

Licensee /

Titulaire de permis : VIGOUR LIMITED PARTNERSHIP ON BEHALF OF
VIGOUR
302 Town Centre Blvd, Suite #200, MARKHAM, ON,
L3R-0E8

LTC Home /

Foyer de SLD : LEISUREWORLD CAREGIVING CENTRE -
MISSISSAUGA
2250 HURONTARIO STREET, MISSISSAUGA, ON,
L5B-1M8

Name of Administrator /

**Nom de l'administratrice
ou de l'administrateur :**

GARY BUTT



**Ministry of Health and
Long-Term Care**

Order(s) of the Inspector

Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

**Ministère de la Santé et
des Soins de longue durée**

Ordre(s) de l'inspecteur

Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

To VIGOUR LIMITED PARTNERSHIP ON BEHALF OF VIGOUR, you are hereby
required to comply with the following order(s) by the date(s) set out below:



**Ministry of Health and
Long-Term Care**

Order(s) of the Inspector

Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

**Ministère de la Santé et
des Soins de longue durée**

Ordre(s) de l'inspecteur

Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

Order # /

Ordre no : 001

Order Type /

Genre d'ordre : Compliance Orders, s. 153. (1) (b)

Pursuant to / Aux termes de :

O.Reg 79/10, s. 19. (4) The licensee of a home to which subsection (2) or (3) applies shall ensure, not later than six months after the day this section comes into force, that the home has guaranteed access to a generator that will be operational within three hours of a power outage and that can maintain everything required under clauses (1) (a), (b) and (c). O. Reg. 79/10, s. 19 (4).

Order / Ordre :

The licensee shall prepare, submit and implement a plan that summarizes how the licensee will ensure that the following will be operational within 3 hours of a power outage;

1. heating system
2. elevator
3. dietary services equipment
4. emergency and life support equipment

Please email the plan to Bernadette.susnik@ontario.ca or fax it to 905-546-8255 by September 30, 2013. The plan shall be implemented within 6 months of the date of the Order.

Note: if an extension of the compliance date is required, please contact the Inspector at least one week before the expiration of the original compliance date.

Grounds / Motifs :



**Ministry of Health and
Long-Term Care**

Order(s) of the Inspector

Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

**Ministère de la Santé et
des Soins de longue durée**

Ordre(s) de l'inspecteur

Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

1. The licensee did not have guaranteed access to a generator that was operational within 3 hours of a power outage and that could maintain the heating system, dietary services equipment (fridges, freezers, steam tables, food processing equipment), elevators and life support equipment (oxygen concentrators, enteral feeding systems, dialysis machines, therapeutic surfaces etc.).

The City of Mississauga, where the home is situated, was affected by a wide area power outage due to a storm beginning at approximately 5:30 p.m. July 8, 2013. The home was without power to operate their heating system (if necessary), dietary services equipment, elevators and life support equipment between 6:00 p.m. July 8, 2013 until 4:00 a.m. July 9, 2013. Approximately 40 residents who were having their dinner meal in the home's main floor dining room became stranded in the dining room between 6:15 p.m. and the following morning. The home's elevators could not be used to transport residents back to their rooms and for those who could not use the stairs, no alternative method of transport was available. Residents were accommodated on their own mattresses within the dining room.

The home's cold holding equipment was not supplied with any back up power and all perishable foods had to be discarded the following morning. None of the meals however were affected and residents received their planned menu items.

The home was able to provide some services (telecommunications, fire alarms, fire panel, partial emergency lighting, door security system, resident-staff communication and response system) over the course of the power outage by using a portable generator.

The administrator provided information that they have a contract with a generator rental agency, however the administrator did not proceed with initiating the delivery of a generator due to the unpredictability of the power outage. (120)

This order must be complied with by /

Vous devez vous conformer à cet ordre d'ici le : Sep 30, 2013



**Ministry of Health and
Long-Term Care**

Order(s) of the Inspector

Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

**Ministère de la Santé et
des Soins de longue durée**

Ordre(s) de l'inspecteur

Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8



Ministry of Health and
Long-Term Care

Order(s) of the Inspector
Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

Ministère de la Santé et
des Soins de longue durée

Ordre(s) de l'inspecteur
Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

REVIEW/APPEAL INFORMATION

TAKE NOTICE:

The Licensee has the right to request a review by the Director of this (these) Order(s) and to request that the Director stay this (these) Order(s) in accordance with section 163 of the Long-Term Care Homes Act, 2007.

The request for review by the Director must be made in writing and be served on the Director within 28 days from the day the order was served on the Licensee.

The written request for review must include,

- (a) the portions of the order in respect of which the review is requested;
- (b) any submissions that the Licensee wishes the Director to consider; and
- (c) an address for services for the Licensee.

The written request for review must be served personally, by registered mail or by fax upon:

Director
c/o Appeals Coordinator
Performance Improvement and Compliance Branch
Ministry of Health and Long-Term Care
1075 Bay Street, 11th Floor
TORONTO, ON
M5S-2B1
Fax: 416-327-7603



**Ministry of Health and
Long-Term Care**

Order(s) of the Inspector

Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

**Ministère de la Santé et
des Soins de longue durée**

Ordre(s) de l'inspecteur

Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

When service is made by registered mail, it is deemed to be made on the fifth day after the day of mailing and when service is made by fax, it is deemed to be made on the first business day after the day the fax is sent. If the Licensee is not served with written notice of the Director's decision within 28 days of receipt of the Licensee's request for review, this(these) Order(s) is(are) deemed to be confirmed by the Director and the Licensee is deemed to have been served with a copy of that decision on the expiry of the 28 day period.

The Licensee has the right to appeal the Director's decision on a request for review of an Inspector's Order(s) to the Health Services Appeal and Review Board (HSARB) in accordance with section 164 of the Long-Term Care Homes Act, 2007. The HSARB is an independent tribunal not connected with the Ministry. They are established by legislation to review matters concerning health care services. If the Licensee decides to request a hearing, the Licensee must, within 28 days of being served with the notice of the Director's decision, give a written notice of appeal to both:

Health Services Appeal and Review Board and the Director

Attention Registrar
151 Bloor Street West
9th Floor
Toronto, ON M5S 2T5

Director
c/o Appeals Coordinator
Performance Improvement and Compliance
Branch
Ministry of Health and Long-Term Care
1075 Bay Street, 11th Floor
TORONTO, ON
M5S-2B1
Fax: 416-327-7603

Upon receipt, the HSARB will acknowledge your notice of appeal and will provide instructions regarding the appeal process. The Licensee may learn more about the HSARB on the website www.hsarb.on.ca.



Ministry of Health and
Long-Term Care

Order(s) of the Inspector
Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

Ministère de la Santé et
des Soins de longue durée

Ordre(s) de l'inspecteur
Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

RENSEIGNEMENTS SUR LE RÉEXAMEN/L'APPEL

PRENDRE AVIS

En vertu de l'article 163 de la Loi de 2007 sur les foyers de soins de longue durée, le titulaire de permis peut demander au directeur de réexaminer l'ordre ou les ordres qu'il a donné et d'en suspendre l'exécution.

La demande de réexamen doit être présentée par écrit et est signifiée au directeur dans les 28 jours qui suivent la signification de l'ordre au titulaire de permis.

La demande de réexamen doit contenir ce qui suit :

-
- a) les parties de l'ordre qui font l'objet de la demande de réexamen;
 - b) les observations que le titulaire de permis souhaite que le directeur examine;
 - c) l'adresse du titulaire de permis aux fins de signification.

La demande écrite est signifiée en personne ou envoyée par courrier recommandé ou par télécopieur au:

Directeur
a/s Coordinateur des appels
Direction de l'amélioration de la performance et de la conformité
Ministère de la Santé et des Soins de longue durée
1075, rue Bay, 11^e étage
Ontario, ON
M5S-2B1
Fax: 416-327-7603

Les demandes envoyées par courrier recommandé sont réputées avoir été signifiées le cinquième jour suivant l'envoi et, en cas de transmission par télécopieur, la signification est réputée faite le jour ouvrable suivant l'envoi. Si le titulaire de permis ne reçoit pas d'avis écrit de la décision du directeur dans les 28 jours suivant la signification de la demande de réexamen, l'ordre ou les ordres sont réputés confirmés par le directeur. Dans ce cas, le titulaire de permis est réputé avoir reçu une copie de la décision avant l'expiration du délai de 28 jours.



**Ministry of Health and
Long-Term Care**

Order(s) of the Inspector

Pursuant to section 153 and/or
section 154 of the *Long-Term Care
Homes Act, 2007*, S.O. 2007, c.8

**Ministère de la Santé et
des Soins de longue durée**

Ordre(s) de l'inspecteur

Aux termes de l'article 153 et/ou
de l'article 154 de la *Loi de 2007 sur les foyers
de soins de longue durée*, L.O. 2007, chap. 8

En vertu de l'article 164 de la Loi de 2007 sur les foyers de soins de longue durée, le titulaire de permis a le droit d'interjeter appel, auprès de la Commission d'appel et de révision des services de santé, de la décision rendue par le directeur au sujet d'une demande de réexamen d'un ordre ou d'ordres donnés par un inspecteur. La Commission est un tribunal indépendant du ministère. Il a été établi en vertu de la loi et il a pour mandat de trancher des litiges concernant les services de santé. Le titulaire de permis qui décide de demander une audience doit, dans les 28 jours qui suivent celui où lui a été signifié l'avis de décision du directeur, faire parvenir un avis d'appel écrit aux deux endroits suivants :

À l'attention du registraire
Commission d'appel et de révision
des services de santé
~~151, rue Bloor Ouest, 9e étage~~
Toronto (Ontario) M5S 2T5

Directeur
a/s Coordinateur des appels
Direction de l'amélioration de la performance et de la
conformité
Ministère de la Santé et des Soins de longue durée
1075, rue Bay, 11e étage
Ontario, ON
M5S-2B1
Fax: 416-327-7603

La Commission accusera réception des avis d'appel et transmettra des instructions sur la façon de procéder pour interjeter appel. Les titulaires de permis peuvent se renseigner sur la Commission d'appel et de révision des services de santé en consultant son site Web, au www.hsarb.on.ca.

Issued on this 13th day of August, 2013

Signature of Inspector /

Signature de l'inspecteur :

Name of Inspector /

Nom de l'inspecteur :

BERNADETTE SUSNIK

Service Area Office /

Bureau régional de services : Hamilton Service Area Office