



**Ministry of Health and
Long-Term Care**

**Inspection Report under
the Long-Term Care
Homes Act, 2007**

**Ministère de la Santé et des
Soins de longue durée**

**Rapport d'inspection
prévus le Loi de 2007 les
foyers de soins de longue**

Health System Accountability and Performance
Division

Performance Improvement and Compliance Branch

Division de la responsabilisation et de la
performance du système de santé

Direction de l'amélioration de la performance et de la
conformité

Hamilton Service Area Office
119 King Street West, 11th Floor
HAMILTON, ON, L8P-4Y7
Telephone: (905) 546-8294
Facsimile: (905) 546-8255

Bureau régional de services de Hamilton
119, rue King Ouest, 11^{ième} étage
HAMILTON, ON, L8P-4Y7
Téléphone: (905) 546-8294
Télécopieur: (905) 546-8255

Public Copy/Copie du public

Date(s) of inspection/Date(s) de l'inspection	Inspection No/ No de l'inspection	Type of Inspection/Genre d'inspection
Aug 1, 2012	2012_072120_0056	Follow up

Licensee/Titulaire de permis

NIAGARA HEALTH SYSTEM
63 THIRD STREET, WELLAND HOSPITAL SITE, WELLAND, ON, L3B-4W6

Long-Term Care Home/Foyer de soins de longue durée

NIAGARA HEALTH SYSTEM, WELLAND HOSPITAL SITE, EXTENDED CARE UNIT
155 Ontario Street, St. Catharines, ON, L2R-5K3

Name of Inspector(s)/Nom de l'inspecteur ou des inspecteurs

BERNADETTE SUSNIK (120)

Inspection Summary/Résumé de l'inspection

The purpose of this inspection was to conduct a Follow up inspection.

During the course of the inspection, the inspector(s) spoke with the administrator regarding the door access control systems. (H-001516-12)

During the course of the inspection, the inspector(s) observed and tested all perimeter doors leading to non-enclosed outdoor areas to ensure that the magnetic locks, key pads and alarms functioned as intended and ensured that the door access control systems are connected to an audio visual enunciator.

An inspection (2011-159120-018) was conducted on July 7, 2011, at which time Order #001 was issued for non-compliance with sections 9.1.i., ii., and iii of Ontario Regulation 79/10. For this follow-up visit, the Order has been complied with and is in compliance.

The following Inspection Protocols were used during this inspection:

Safe and Secure Home

There are no findings of Non-Compliance as a result of this inspection.

NON-COMPLIANCE / NON-RESPECT DES EXIGENCES



Ministry of Health and
Long-Term Care

Inspection Report under
the Long-Term Care
Homes Act, 2007

Ministère de la Santé et des
Soins de longue durée

Rapport d'inspection
prévus le Loi de 2007 les
foyers de soins de longue

Legend	Legendé
WN – Written Notification	WN – Avis écrit
VPC – Voluntary Plan of Correction	VPC – Plan de redressement volontaire
DR – Director Referral	DR – Aiguillage au directeur
CO – Compliance Order	CO – Ordre de conformité
WAO – Work and Activity Order	WAO – Ordres : travaux et activités
Non-compliance with requirements under the Long-Term Care Homes Act, 2007 (LTCHA) was found. (A requirement under the LTCHA includes the requirements contained in the items listed in the definition of "requirement under this Act" in subsection 2(1) of the LTCHA.)	Le non-respect des exigences de la Loi de 2007 sur les foyers de soins de longue durée (LFSLD) a été constaté. (Une exigence de la loi comprend les exigences qui font partie des éléments énumérés dans la définition de « exigence prévue par la présente loi », au paragraphe 2(1) de la LFSLD.)
The following constitutes written notification of non-compliance under paragraph 1 of section 152 of the LTCHA.	Ce qui suit constitue un avis écrit de non-respect aux termes du paragraphe 1 de l'article 152 de la LFSLD.

THE FOLLOWING NON-COMPLIANCE AND/OR ACTION(S)/ORDER(S) HAVE BEEN COMPLIED WITH/
LES CAS DE NON-RESPECTS ET/OU LES ACTIONS ET/OU LES ORDRES SUIVANT SONT MAINTENANT
CONFORME AUX EXIGENCES:

CORRECTED NON-COMPLIANCE/ORDER(S) REDRESSEMENT EN CAS DE NON-RESPECT OU LES ORDERS:			
REQUIREMENT/ EXIGENCE	TYPE OF ACTION/ GENRE DE MESURE	INSPECTION # / NO DE L'INSPECTION	INSPECTOR ID #/ NO DE L'INSPECTEUR
O.Reg 79/10 r. 9.	CO #001	2011-159120-018	120

Issued on this 15th day of August, 2012

Signature of Inspector(s)/Signature de l'inspecteur ou des inspecteurs

B. Lussier