

Independent Electricity Market Operator

***18-Month Outlook:***

---

***An Assessment of the Adequacy of the Ontario Electricity  
System***

***From October 2000 to March 2002***

November 17, 2000

## Executive Summary

This report presents an assessment of the generation and transmission adequacy of the Ontario electricity system for the 18-month period from October 2000 through March 2002. The assessment is based on a forecast of electricity demand and available supply combined with current information on the configuration and capability of the transmission system. The most recent known outage plans of generators and transmitters are incorporated in the assessment.

Resource Margins in Ontario are forecast to be manageable for the entire period.

Detailed Margin analysis was conducted in accordance with the Transitional IMO License – EI-1999-0450..

Ontario Power Generation has declined to give the IMO permission to publish these resource adequacy details for as long as Ontario Power Generation has the obligation to supply the Ontario Electricity System. The IMO is required to respect Ontario Power Generation's position as a condition of the Transitional IMO License.

Ontario Power Generation will manage the Margins through a combined use of its own generation, load management, rescheduling of outages and supply from interconnected control areas.

The transmission outage plan has been reviewed for system impacts. Results of this assessment indicate the following:

Although the forecast available generation margins are generally manageable in the study period, any outages that may affect interconnection support or generation access to the IMO-Controlled Grid should be coordinated closely between the transmitter and the generators involved. The analysis highlighted a few outages with this potential impact. In addition, the impacts of some forced outages have been noted.

System voltage concerns during times of extreme summer peak demands, will limit the flexibility for planning outages in the Toronto and Windsor areas in 2001.

Restoration of the reactive power output capability of Darlington and Pickering units could reduce the stated voltage concerns in the Toronto area.

### **Caution and Disclaimer**

The contents of these materials are for discussion and information purposes and are provided “as is” without representation or warranty of any kind, including without limitation, accuracy, completeness or fitness for any particular purpose. The Independent Electricity Market Operator (IMO) assumes no responsibility to you or any third party for the consequences of any errors or omissions. The IMO may revise these materials at any time in its sole discretion without notice to you. Although every effort will be made by the IMO to update these materials to incorporate any such revisions it is up to you to ensure you are using the most recent version.

## Table of Contents

|                                                            |           |
|------------------------------------------------------------|-----------|
| <b>Executive Summary.....</b>                              | <b>ii</b> |
| <b>1.0 Introduction.....</b>                               | <b>1</b>  |
| <b>2.0 Forecast of Ontario Electricity Demand .....</b>    | <b>2</b>  |
| 2.1 Forecasting Process .....                              | 2         |
| 2.2 Forecast Drivers.....                                  | 3         |
| 2.3 Forecast of Energy Demand .....                        | 4         |
| 2.4 Forecast of Peak Demand .....                          | 5         |
| <b>3.0 Resources .....</b>                                 | <b>7</b>  |
| 3.1 Generating Capacity Included in the Assessment.....    | 7         |
| 3.2 External Transactions .....                            | 7         |
| 3.3 Summary of Available Resources.....                    | 8         |
| 3.4 Potential New Generation Sources.....                  | 8         |
| <b>4.0 Resource Assessment.....</b>                        | <b>10</b> |
| 4.1 Methodology to Assess Resource Adequacy .....          | 10        |
| 4.2 Summary of Resource Adequacy .....                     | 11        |
| <b>5.0 The Ontario Electricity System .....</b>            | <b>13</b> |
| 5.1 Current Configuration of the Transmission System ..... | 13        |
| <b>6.0 Transmission Adequacy Assessment.....</b>           | <b>15</b> |
| 6.2 Assessment of Transmission Outage Plan.....            | 15        |
| 6.3 System Voltage Concerns .....                          | 17        |
| 6.4 Forced Outages .....                                   | 17        |
| 6.5 Summary.....                                           | 18        |
| <b>7.0 Overall Findings and Conclusions .....</b>          | <b>19</b> |

## Table of Appendices

|                                                       |
|-------------------------------------------------------|
| <b>Appendix A Electricity Demand Forecast Details</b> |
| <b>Appendix B Ontario Electricity System - Maps</b>   |
| <b>Appendix C System Resources Details</b>            |
| <b>Appendix D Transmission System Details</b>         |

## List of Tables

|                                                                        |   |
|------------------------------------------------------------------------|---|
| Table 2.1 Ontario Energy Demand .....                                  | 4 |
| Table 3.1 Summary of Generation Assumed Available at Winter Peak ..... | 9 |

## List of Figures

|                                                                                                                                |    |
|--------------------------------------------------------------------------------------------------------------------------------|----|
| Figure 2.1 Monthly Total System Primary Energy Demand Forecast Weather Normal .....                                            | 5  |
| Figure 2.2 Forecast of Weekly 20-minute Total System Peak Demand Normal Weather .....                                          | 6  |
| Figure 4.1 18 - Month Forecast of Gross Resource Adequacy .....                                                                | 12 |
| Figure 4.2 Gross Margins .....                                                                                                 | 12 |
| Figure 5.1 Significant Internal Ontario Transmission Interfaces and Points of Interconnection With<br>Neighbouring Areas ..... | 14 |

## 1.0 Introduction

When put in force in 2001, the Ontario Electricity Market Rules (Chapter 5) will require that the Independent Electricity Market Operator (IMO) provide forecasts and assessments of the adequacy of the existing and committed generation and transmission facilities after market opening. Until that time, a condition of the Transitional License for the IMO (Section 18.1) requires the IMO to monitor the state of electricity demand and available supply in Ontario.

To meet these obligations, the IMO published<sup>1</sup> the first 18-Month Outlook in March 2000 and the first 10-Year Outlook in August 2000.

In October, 2000, the IMO updated the original 18-Month Outlook to cover the period from October 2000 until March 2002. This is a public version of the 18-Month Outlook, derived the IMO's detailed analysis by eliminating all the information that, in the opinion of stakeholders, is commercially sensitive. The IMO is prevented from publishing this information under Section 19 of its Transitional License.

Section 2 of this report provides an 18-Month forecast of electricity demand for Ontario. The generation capacity that is expected to be available during the study period is summarized in Section 3, and an assessment of the adequacy of the generation capacity under the current generation maintenance outage program is presented in Section 4. The transmission system that is expected to be available is described in Section 5 and the current transmission outage plan is assessed in Section 6. The findings and conclusions of this assessment are contained in Section 7.

Readers are invited to provide comments on this report or to give suggestions as to the content of future reports. To do so, please call the IMO Help Centre at 416-506-2836 or send an email to [forecasts.assessments@theIMO.com](mailto:forecasts.assessments@theIMO.com).

---

<sup>1</sup> IMO Website [www.theIMO.com](http://www.theIMO.com) (Months and Years Ahead)

## 2.0 Forecast of Ontario Electricity Demand

The Ontario Primary Demand is the sum of coincident load demands plus the losses on the transmission and distribution systems. Ontario Primary Demand does not include loads that are supplied by embedded generation.

Section 2.1 describes the process used to forecast electricity demand for this report. Section 2.2 looks at the factors that shape the demand for electricity. Section 2.3 summarizes the current energy demand forecast, while Section 2.4 summarizes the peak demand forecast. A detailed forecast of total demand and demand by transmission zone is shown in Appendix A.

### 2.1 Forecasting Process

The forecast of Ontario electricity demand used in this assessment was produced by the IMO utilizing information provided by Ontario Power Generation Inc (OPGI). Both the methodology and the OPGI supplied information are consistent with the 10-year demand forecast found in the IMO's current 10-Year Outlook. Recent actual energy demand shows stronger growth than the trend in the IMO's current 10-Year outlook. For this reason, a scenario with higher peak demand is included in the assessment discussed in Section 4.

The demand for electricity in Ontario was analyzed for the Northwest portion of the province separately from the remainder of the province. This separation is necessary due to the difference in scale and behaviour of the two systems. The Northwest system accounts for roughly 5% of the total energy demand on the system, and the climate and mix of end-uses make the Northwest system profile significantly different from that of the remainder of the province.

Demand is divided into three large and distinct blocks for each subsystem identified above. These blocks are identified as cooling load, heating load and base load. Each of these blocks was forecast individually, then summed to derive the system electricity demand. Growth projections were derived for each of the blocks or components based on historical relationships and future trends. Each of these components is shaped by the same environmental factors however the impacts of these factors vary by demand component.

Forecasts of peak demands were calculated using historical peak-to-energy demand relationships. Statistics were also produced for variance of the peak demands in each week to reflect the impact of weather.

For input into the assessment study, the following forecasts were developed:

Separate forecasts of the 20-minute peak demand for the Northwest and the remainder of the province, as well as the coincident total system peak demand (under Weather Normal conditions);

hourly energy demand by region (under Weather Normal conditions);

statistics on the variance in the peak and energy demand in each week to reflect the impact of weather.

For the purposes of the forecast, weather is not explicitly forecast; rather a "Weather Normal" forecast of electricity demand is produced. Combining the current economic model and a

sample of representative weather conditions generates Weather Normal numbers. This sample is comprised of weather conditions for the same period over the last 30 years. This results in a distribution of potential values for the period in question. The median value of the distribution is termed the Weather Normal.

The process of forecasting will continue to evolve at the IMO as experience is gained and the energy modeling increases in sophistication. After market opening, a range of new forces will come into play that will change the dynamics of Ontario's electricity demand and the IMO forecasting process will evolve with these changes. With very few registration applications received to date from price-responsive loads, it is too soon to include estimates of their impact on overall Ontario demand.

## 2.2 Forecast Drivers

The consumption of energy is driven by a variety of factors, from weather to the behaviour of homeowners to changes in technology. Weather has by far the greatest impact on consumption, but great volatility and unpredictability also characterize it. For this reason, modeling is done on a weather normal basis. Without weather as an explanatory variable, economic, end-use and technology factors shape the growth of consumption. The key drivers shaping the underlying trends for each of the demand components are discussed below.

**Cooling Load** is primarily comprised of space cooling or air-conditioning demands which are highly sensitive to heat and humidity. Aside from variations due to weather conditions, growth in cooling load will depend on the end-user. Unlike some other end-uses, electric air-conditioning does not yet have a viable non-electric competitor. Therefore, demand grows with additions to housing stock and commercial floor-space, as well as with increased manufacturing activity.

The increased penetration of space cooling in the residential market means that the cooling load will grow faster than the housing stock. Although commercial development has mostly languished since the late 1980's, economic activity over the last several years has led to a rebound in growth in floor-space – particularly in the “Big Box” retail segment.

Over the last three years (1997-99) Ontario built 163,000 new homes and is expected to add an additional 210,000 over the 2000-02 time frame. With new housing activity remaining strong over the forecast period and commercial construction activity picking up, cooling load is expected to experience strong growth (2.0% per annum) throughout the 18 month forecast.

**Heating Load** is weather-sensitive winter load. Aside from weather variations, the growth in heating load will also be determined by the end-user. Unlike cooling load, heating load is subject to strong competition from other energy sources, in particular natural gas. Over the late 1980's and early 1990's, natural gas prices were falling as electricity prices were increasing, triggering a decade long phase of fuel switching. At the same time prices were changing, the efficiency of oil and natural gas equipment was increasing, adding further incentive to switch fuels. Therefore, as space-heating equipment reached the end of its useful life or the payback justified it, electric heating equipment has been replaced by natural gas or oil fired equipment. Electric heating is rare in new homes and fuel switching of existing customers will continue.

Despite its competitive price disadvantage, electricity does still have a significant heating load. Due to technological issues, some fuel switching is not economical – in particular; baseboard

heaters do not have an economic substitute. Natural gas is limited to the area served by its distribution system. As well, the price advantage enjoyed by oil and natural gas has eroded recently. The loss of customers to fuel switching has slowed and, combined with modest heating additions, heating load will remain flat over the forecast.

**Base Load** represents the non-weather sensitive portion of demand. Contributing factors include lighting, water heating and industrial machinery. Since this load is not weather dependant, growth will be driven by economic activity.

Currently, the strong U.S. economy, combined with the low Canadian dollar, has been a boon to Ontario's exporters. Energy intensive industries such as transportation equipment, pulp & paper and steel have seen their competitive advantage increase with the dollar's decline. Domestic demand has continued to strengthen on the back of strong employment growth and relatively low interest rates. Despite a recent slowing of U.S. economic growth, domestic demand and international competitiveness will ensure robust growth in manufacturing activity over the forecast period. Offsetting some of the increased load from economic expansion will be base load lost to self-generation and fuel switching. Despite the addition of 435,000 jobs over the 2000-02 time frame, load loss will keep base load growth at 1.0% per annum over the forecast period.

## 2.3 Forecast of Energy Demand

Actual primary energy demand has averaged annual growth of 1.4% over the period 1986-1999. Although this report is for an 18-Month forecast (Oct-2000 to Mar-2002), a figure for 2002 is provided in order to calculate annual growth. The predicted energy demand and corresponding growth rates are detailed in Table 2.1. Figure 2.1 graphically displays energy demand on a monthly basis. As Table 2.1 indicates, energy demand is expected to grow by 1.16% over the forecast period. The growth comes from the combined effects of the projected cooling, heating and base load growth. The impact of recent higher trends in energy demand will be captured in the next update. Base load growth from economic activity and cooling load growth from increased air-conditioning penetration are the reasons for the growth in energy demand.


**Table 2.1 Ontario Energy Demand**

| Year                                     | Weather Normal<br>Energy Demand (TWh) | Actual Weather <sup>2</sup><br>Energy Demand (TWh) |
|------------------------------------------|---------------------------------------|----------------------------------------------------|
| 1995                                     | 137.5                                 | 137.0                                              |
| 1996                                     | 138.8                                 | 137.4                                              |
| 1997                                     | 139.7                                 | 138.4                                              |
| 1998                                     | 141.6                                 | 139.9                                              |
| 1999                                     | 144.8                                 | 144.1                                              |
| 2000                                     | 147.6 (forecast)                      |                                                    |
| 2001                                     | 148.6 (forecast)                      |                                                    |
| 2002 <sup>3</sup>                        | 149.9 (forecast)                      |                                                    |
| Average Annual Growth 1999-2002 is 1.16% |                                       |                                                    |

<sup>2</sup> For the years 2000 to 2002, the forecast energy for Actual is the same as the forecast for Weather Normal since weather is not forecast for the planning period.

<sup>3</sup> The forecast only extends to Mar-02, however an annual figure is provided.

**Figure 2.1 Monthly Total System Primary Energy Demand Forecast  
Weather Normal**



## 2.4 Forecast of Peak Demand


Historically, Ontario's electricity peak demand has occurred during the winter, usually in the months of December through February and between the hours of 5 p.m. to 7 p.m. Exceptions to this were in 1998 and 1999, when the annual peak demand occurred during the afternoon of early to mid-July. The occurrence of this summer vs. winter peak demand is attributed to a warmer than normal winter and unusually hot summer weather as a result of El Nino and La Nina. The actual Ontario all-time 20-minute peak demand reached 24,007 MW in January 1994 and the highest summer peak was 23,435 MW in 1999. The actual 20-minute winter peak demand in 2000 was 23,428 MW (Monday, January 17) and the actual summer peak demand in 2000 was 23,222 MW (Thursday, August 31). Recent higher energy demand is not reflected in a higher actual peak demand, mainly due to moderate weather during the past year. However, a scenario of about 300 MW higher peak demand, in winter and summer, is included in the assessment of resources.

The winter and summer peak demands are very weather dependent and usually coincide with extreme weather conditions. The growth in the summer peak is determined by the growth in base load and cooling load. Conversely, the growth in the winter peak is determined by the growth in base load and heating load. Based on the discussion under section 2.2, it is not surprising that we have seen a lower response for energy during periods of cold temperatures and a higher response for energy during periods of hot temperatures. Over the 1986-1999 time frame, the winter peak demand has averaged annual growth of 0.9% while the summer peak

demand has averaged annual growth of 2.6%, testimony to the underlying trends affecting the two.

Although the system will remain winter peaking throughout this forecast, the summer peak demand will grow faster than the winter peak demand in this forecast. Figure 2.2 displays the forecast weekly peak demand measured over a 20-minute period. Further details of the peak forecast are included in Appendix A.

**Figure 2.2 Forecast of Weekly 20-minute Total System Peak Demand  
Normal Weather**



## **3.0 Resources**

This section describes the generating resources that are forecast to be available over the 18-Month assessment period from October 1, 2000 to March 31, 2002.

Section 3.1 describes the declared net capacity of the generation resources and Section 3.2 describes the bilateral external transactions (imports and exports). Section 3.3 provides an overall summary of the available resources that are included in the assessment after taking into account various reductions and external transactions.

### **3.1 Generating Capacity Included in the Assessment**

#### **Generation from Ontario Power Generation Inc. (OPGI)**

The OPGI generation included in the study is shown in Appendix C, Table C1.1. The generation mix includes nuclear, coal, oil and gas-fuelled generation, as well as hydroelectric and wind-powered stations. Also shown in Appendix C are the OPGI generators that are not included as resources in this assessment.

Bruce Power will assume control over the Bruce plants after it is granted an operating license by the Canadian Nuclear Safety Commission and the Ontario Energy Board. These approvals are expected by late spring or early summer 2001.

#### **Committed Additional OPGI Resources**

Over the next several years, OPGI plans to undertake a number of upgrades at various hydroelectric stations, in order to increase the output of their units. Only 30 MW of planned upgrades (after Year 2000) have been committed at this time.

#### **Generation from Contract Generators**

Contract Generators are generators that have contracts with the Ontario Electricity Financial Corporation (OEFC) to deliver defined amounts of capacity and energy. This generation includes hydroelectric generation as well as waste-fuelled and natural gas-fuelled thermal generation as shown in Appendix C. The installations range in size from about 1 MW to 165 MW resulting in a total capacity of 1,766 MW at winter peak. The production forecast for Contract Generators was provided by Hydro One Networks Inc.

### **3.2 External Transactions**

OPGI has existing contracts for the purchase of up to 1000 MW until December 31, 2000 and 200 MW until October 31, 2003.

No capacity backed sales to other Control Areas have been identified to the IMO.

### **3.3 Summary of Available Resources**

Table 3.1 shows a snapshot of the total available generation capacity at the time of winter peak demand in 2001 and 2002. The available generation (not accounting for planned outages) is forecast to be 26,104 MW at winter peak of 2001 and 26,560 MW at the winter peak of 2002.

#### **Changes from the current 10-Year Outlook**

The available generation (no planned outages) was forecast to be 26,680 MW at winter peak of 2001 and 27,195 MW at winter peak of 2002 in the current 10-Year Outlook. The reduction to available generation included in this 18-Month Outlook is mainly due to a new hydroelectric forecast from OPGI and reductions in capacity due to transmission limitations. The latter reductions were not previously included in stating the Available Resources but were included in the margin calculations.

### **3.4 Potential New Generation Sources**

There are no new generation sources in the assessment period. A status summary of the requests for new connection assessments is available on the IMO's website.

**Table 3.1 Summary of Generation Assumed Available at Winter Peak**

| Notes                             | Year                          | 2001   | 2002   |
|-----------------------------------|-------------------------------|--------|--------|
| <b>Net Capacity</b>               |                               |        |        |
| 1                                 | OPGI Declared Net Capacity    | 27,794 | 27,794 |
| 2                                 | Committed OPGI Generation     | 30     | 30     |
| 3                                 | Contract Generators           | 1,766  | 1,766  |
| 4                                 | Firm Import                   | 200    | 200    |
| 5                                 | Total Declared Net Capacity   | 29,790 | 29,790 |
| <b>Reductions to Net Capacity</b> |                               |        |        |
| 6                                 | Unavailable Capacity          | 2,312  | 1,857  |
| 7                                 | Hydro Plant Reductions        | 1,268  | 1,268  |
| 8                                 | Locked-in Capacity            | 106    | 105    |
| 9                                 | Available Generation Capacity | 26,104 | 26,560 |

**Notes to Table 3.1:**

1. OPGI Declared Net Capacity  
This is the total capacity available from OPGI owned generation units, as declared by OPGI in Table C1.1. This capacity does not include Bruce A.
2. Committed OPGI Generation  
OPGI has committed projects to upgrade some of their facilities. The reported quantity is the expected improvement from these projects. Additional planned upgrades were reported, but these are less certain and have not been included here.
3. Contract Generators  
Hydro One administers Contract Generators on behalf of Ontario Electricity Financial Corporation. The reported amount is the net declared capacity available from the Contract Generators.
4. Firm Import  
At the present time, there is only one firm contract for the import of 200 MW of energy and capacity. This contract ends on October 31, 2003.
5. Total Declared Net Capacity  
This is the sum of net declared generating capacity (MW) from all sources.
6. Unavailable Capacity  
The reported values include the amount of long term outages and the currently known temporary deratings to the Declared Net Capacity (line 5), and are based on information provided by the resource owner (OPGI and Contract Generators).
7. Hydro Plant Reductions  
Reductions to Hydro plants, from the declared net capacity, will vary from month to month. The in-service capacity of OPGI's hydroelectric generation is about 7,280 MW. This number reflects the maximum output from all such stations and, in this report, is reduced by an amount that reflects the expected hydro peak hour production and forced outage reductions, as provided by the owner. Ontario 25 Hz locked-in generation capacity has also been accounted for as a further reduction in this estimate.
8. Locked-in Capacity is the estimated generating capacity locked into local areas due to Operating Security Limits, excluding 25 Hz locked-in generation in Item 7.
9. Available Generation Capacity  
This is the generation capacity available to supply the forecast demand, after all known reductions have been accounted for. It is the net declared capacity less the known deratings and hydroelectric reductions. This quantity does not include any generator outages (planned or unplanned). Planned outages take place mainly in the spring and fall, when the demand is low.

## **4.0 Resource Assessment**

This section provides an assessment of the adequacy of the available generating resources described in Section 3 to meet the forecast demand as described in Section 2. The methodology used to carry out this assessment is summarized in Section 4.1. and is described in more detail in Appendix C. A summary of the adequacy assessment is provided in Section 4.2. All detailed Margin analysis has been removed to meet the conditions of the Transitional Licence of the IMO, Section 19.

### **4.1 Methodology to Assess Resource Adequacy**

#### **4.1.1 Generation Reserve Requirement**

Generation Reserves are required to ensure that the forecast demand can be supplied with a sufficiently high level of reliability. The Generation Reserve Requirement is calculated based upon the NPCC Generation Adequacy Standard. The Required Generation Capacity, is therefore, the amount of generation capacity required to supply the peak demand and meet the Generation Reserve Requirement.

The IMO, as a member of the Northeast Power Coordinating Council (NPCC), is expected to demonstrate that it can achieve the following Generation Adequacy Standard:

"...after due allowance for scheduled outages and deratings, forced outages and deratings, assistance over interconnections with neighboring Areas and regions, and capacity and/or load relief from available operating procedures, the probability of disconnecting non-interruptible customers due to resource deficiencies, on the average, will be no more than once in ten years".

The Generation Reserve Requirement in MW was calculated, for each week in the assessment period, based on the Generation Adequacy Standard described above using the IMO's Load and Capacity Program (see Appendix C for further details). The forecast excess or shortfall (between the Available Generation Reserve and the Generation Reserve Requirement) is termed the Margin. The Margin does not include the additional support that may be available from interconnection assistance or from the dispatching-off of price sensitive loads. The amount of such support will vary depending on price and availability; this variability and range of support is described in the final assessment of adequacy. As mentioned earlier, the explicit values of the Margin are not shown in this version of the report due to the commercial sensitivity of this type of information.

#### **Changes from the current 10-Year Outlook**


The Generation Adequacy Standard is now based directly on the NPCC standard, which is described above. In the previous report the Generation Reserve Requirement was a percentage of the Peak Demand for the period 2000 to 2002. All future assessments will be based on the NPCC standard.

## **4.2 Summary of Resource Adequacy**


The forecast weekly Gross Margin is shown in Figures 4.1 and 4.2. Gross Margin does not include the effect of planned or forced outages to generation resources. It is calculated from information available in the public domain or forecast by the IMO.

Forecast Margins (after accounting for outages) in Ontario are expected to be manageable for the entire period. Ontario Power Generation will manage the Margins through a combined use of its own generation, load management, rescheduling of outages and supply from interconnected control areas. If made necessary due to resource shortfalls, the IMO will implement Emergency Operating Procedures.

**Figure 4.1 18 - Month Forecast of Gross Resource Adequacy**



**Figure 4.2 Gross Margins**



## 5.0 The Ontario Electricity System

### 5.1 Current Configuration of the Transmission System

The existing and committed 500, 230 and 115 kV transmission network is shown in Appendix B (Maps) and Appendix D (Details). Figure 5.1 provides a geographic depiction of Ontario's internal transmission zones, between which there are stated transfer limits, and the points of interconnection with other jurisdictions.

#### 5.1.1 Changes to the Committed Transmission Plan from the Previous Report

Committed transmission facilities are summarized in Appendix D, Section 4. Of special note are construction activities, which are underway to implement the following modifications to the Michigan-Ontario interconnections, with a target completion date of June 2001:

Ontario Facilities:

Parallel the existing two 345/230 kV autotransformers T7 and T8 for connection on the interconnection circuit L4D;

Install two 230 kV, 845 MVA phase shifting transformers, one on the interconnection circuit L4D and one on interconnection circuit L51D.


Michigan Facilities:

Install a 345/230 kV, 1000 MVA autotransformer on the interconnection circuit L51D;

Install a 230 kV, 675 MVA phase shifting transformer on the interconnection circuit B3N.

All of the above facility installations were completed in June 2000 with the exception of the L4D phase shifter which is scheduled to be completed by June 2001. These modifications will increase the Ontario-Michigan interconnection capability as shown in Appendix D, Table D3.1. The new phase shifting transformers, with an effective phase angle control range of  $\pm 40$  degrees under full load will provide the capability of controlling Lake Erie Circulation (LEC) by approximately 500 to 600 MW. Details are provided in Appendix D, Section 1.4.

**Figure 5.1 Significant Internal Ontario Transmission Interfaces and Points of Interconnection With Neighbouring Areas**



**Major Interface Capability**

|                                                         |                                                     |
|---------------------------------------------------------|-----------------------------------------------------|
| Manitoba Interconnection *                              | 288 in or out Summer / 300 in or out Winter         |
| * limited to 163 summer, 190 winter until December 2001 |                                                     |
| Minnesota Interconnection                               | 100 in, 150 out                                     |
| East-West Tie                                           | 325 E, 350 W                                        |
| Flow North Interface                                    | 1900                                                |
| Flow South Interface                                    | 1400                                                |
| CLAN Interface                                          | 2000                                                |
| CLAS Interface                                          | 1000                                                |
| FABC Interface                                          | 5200, normally not limiting                         |
| HQ Interconnection                                      | 1394 in, 530 out Summer / 1408 in, 530 out Winter   |
| New York Interconnection                                | 1850 in, 2350 out Summer / 2150 in, 2450 out Winter |
| Michigan Interconnection                                | 1500 in, 2350 out Summer / 1600 in, 2400 out Winter |
| Buchanan Longwood Input (BLIP)                          | 3500                                                |
| Negative BLIP                                           | 1500                                                |
| Queenston Flow West (QFW)                               | 1800 Summer / 2000 Winter                           |
| Flow East to Toronto (FETT)                             | 5700                                                |

## 6.0 Transmission Adequacy Assessment

The principal purpose of this transmission adequacy assessment is to identify any transmission limits of concern in the next 18 months and to highlight transmission outages that should be rescheduled or coordinated with generation outages to mitigate system reliability concerns.

Planned transmission outages have been provided by Hydro One for the calendar year 2000. Planned transmission outages for 2001 are currently being developed by Hydro One and will be available for the next 18-Month Outlook. The transmitters and generator owners are expected to have a mutual interest in developing an ongoing arrangement to coordinate their outage planning activities. The IMO has an obligation to review the integrated plans of generators and transmitters to identify situations that may adversely impact the operation of the system and to notify the affected participants of these impacts. Prior to this report, the IMO has identified to Hydro One certain planned outage situations that could potentially impact the reliability of the system. Hydro One has responded to this information with appropriate changes in their outage plan. The latest transmission outage plan has been provided by Hydro One for this assessment.

The scope of the transmission assessment for this report is outlined in Section 6.1. The primary assessment is contained in Section 6.2, while voltage and other concerns that may impact on system operation in the study period are outlined in Sections 6.3 and 6.4. A summary of the adequacy of the transmission system is provided in Section 6.5.

### 6.1 Planned Transmission Outages

Hydro One's Transmission Outage Plan is shown in Appendix D, Section 5. The outage plan includes outages for voltage levels of 115 kV and higher and with a duration longer than 5 days. The following items are listed for each outage, with the first and third item having been provided by Hydro One:

- 1) Description of the outaged transmission element
- 2) Transmission Zone (as defined in Appendix D, Section 1.3 of this report)
- 3) Start & Finish Dates, Outage type (continuous or otherwise) and Recall Time,
- 4) IMO's statement about any reduction in the Interface Limits (defined in Appendices D, Sections 2 and 3) or a reduction in a limit internal to the Transmission Zones.
- 5) A qualitative statement from the IMO about the impact of any reduction in transmission limits including any impact on generation.

### 6.2 Assessment of Transmission Outage Plan

The IMO's assessment of the impact of the Transmission outage plan provided by Hydro One is shown in Appendix D (Tables D5.1 to D5.9). In these tables, each element in Hydro One's outage plan is assessed individually and the reduction in transmission limits and possible impacts are noted. A further analysis of overlapping outages did not result in the identification of any further impacts other than those outlined in this section.

Given that the available generation margins are low at times in the study period, outages that may affect interconnection support or generation access to the IMO-Controlled Grid should be coordinated with the generator owners involved. The analysis highlighted a few outages with potential impact as summarized below:

#### **Northwest and Northeast Transmission Zones**

Several outages are scheduled in the above zones but only the following outage may limit generation in the Northwest system due to the identified reduction of 105 MW to the limit in the transfer capability between the Northwest and the Northeast system:

Item #110      circuit P26W between Mississagi and Wawa

#### **Toronto Transmission Zone**

One outage to the 500-kV system, listed below, will reduce interconnection transmission capability from the USA:

Item #80      Circuit B560V from Bruce A to Claireville will reduce the Negative BLIP<sup>4</sup> limit which in turn will reduce import capability from the USA, coincident with negative Generation Margins in October 2000.

#### **West Transmission Zone**

The following transmission outages will reduce interconnection transmission capability with Michigan for a number of weeks in November and December 2000. These outages raise minimal concerns since generation margins are adequate but could become impactful if generation outages in October are not completed as planned:

Item #104      Circuit J5D, Keith to Waterman, 230kV

Item #111      Circuit B563L, Bruce B to Longwood, 500kV

#### **East Transmission Zone**

Some 115kV outages will require careful coordination with generation schedules to limit bottling of generation:

Items #23, #87 and #88 impacting Eastern Ontario 115kV circuits

Item 129 Interconnection circuit B31L between Ontario and Quebec will limit the import capability from Quebec during the winter peak period although the generation margins are forecast to be adequate.

In summary, only a few of the planned outages will potentially impact the generation system. The outages with the highest impact are listed above.

---

<sup>4</sup> Buchanan Longwood Input - BLIP

### 6.3 System Voltage Concerns

Low system voltage concerns particularly in the Windsor and Greater Toronto Area will limit the generation and transmission outages that can be planned during summer peak demand periods. The various system voltage concerns are described below:

In the Windsor area, load growth is stressing the capability of the existing system under extreme-weather, summer peak conditions, when voltages are expected to be near the low end of the acceptable range. Voltage control is acceptable but may require restrictions on the use of the J5D interconnection for exporting power to Michigan. Planned outages to generating units or transmission circuits in the Windsor and Sarnia area should therefore be avoided during the summer peak period.

Studies conducted for summer 2000 are applicable to the summer 2001 forecast period and indicate that voltage control in the Greater Toronto Area (GTA) is acceptable but with little or no margin for contingencies. The planned outage of one Pickering B generating unit can be accommodated but system voltages are expected to be at or near their acceptable minimum values, and require the availability of the remaining four Lakeview, three Pickering B and four Darlington units. Planned outages to these units should be scheduled outside the summer peak periods. These studies assumed that all but two Darlington units can supply their designed reactive output capability at rated MW output, and that all other reactive sources and transmission elements in the GTA are available. Above the forecast extreme-weather 2001 summer peak demand (of 24,254 MW), voltages in the GTA can be expected to drop 1.5 kV for each additional 100 MW of demand (at 0.9 power factor). This means that precontingency actions may be necessary to manage the risk of the loss of an additional large generating unit. The historical, lower-than-rated equipment performance, of some Pickering and Darlington units in providing rated reactive power during hot weather further erodes any available voltage control margins in the area. Restoration of the rated reactive output capability of these units will reduce the stated voltage concerns.

At least one of the three generators at Thunder Bay is required to be in-service, most of the time, to maintain minimum voltages in the area, at times of normal industrial demand.

### 6.4 Forced Outages

The following ongoing forced outages will affect outage planning:

Manitoba-Ontario tie K22W is currently unavailable due to the forced outage of the phase-shifting transformer. This has reduced the transfer capability between Manitoba and Ontario, and has somewhat restricted the flexibility for Manitoba Hydro and OPGI in their existing interchange agreements. The outage also reduces the East-West tie capability, in the order of 50 to 100 MW, further reducing dispatching flexibility in the Northwest zone and requiring more coordination in planning transmission and generation outages

Lennox T52 autotransformer is unavailable due to a forced outage. The most significant impacts of the outage are reductions to the flexibility to dispatch Lennox and reduced ability to plan outages to the remaining Lennox T51. Under summer conditions, with heavy imports from Beauharnois, and reduced output at Darlington, transformer T51 can be loaded up to its continuous rating and may require one of Unit 3 or 4 operating at Lennox to reduce flows.

Outages to T51 make the Lennox reactors unavailable and may require Lennox unit operation to control voltages at Lennox.

## **6.5 Summary**

The transmission outage plan has been reviewed for system impacts. Forecast generation reserve margins are such that any outages that may affect interconnection support or generation access to the IMO-Controlled Grid should be coordinated closely between the transmitter and the generators involved. Some of these outages are highlighted in the body of this report; the remainder are addressed in Appendix D. Several other locally impactful transmission outages, that require careful coordination with local generators, are also identified. In addition, the impact of forced transmission outages has been noted.

System voltage concerns during times of expected summer peak demands, will limit the flexibility for planning outages in the Toronto and Windsor areas. Restoration of the reactive power output capability of Darlington and Pickering units would reduce the stated voltage concerns in the Toronto area.

## 7.0 Overall Findings and Conclusions

An assessment of the generation and transmission adequacy of the Ontario Electricity System has been carried out for the period from October 2000 through March 2002. The assessment is based on a forecast of electricity demand and available supply combined with current information on the configuration and capability of the transmission system. The most recent known outage plans of generators and transmitters are incorporated in the assessment.

Forecast Margins in Ontario are expected to be manageable for the entire period.

Ontario Power Generation will manage the Margins through a combined use of its own generation, load management, rescheduling of outages and supply from interconnected control areas.

If necessary due to resource shortfalls, the IMO will implement Emergency Operating Procedures.

The transmission outage plan has been reviewed for system impacts and the results of this review indicate the following:

Although the forecast available generation margins are generally manageable in the study period, any outages that may affect interconnection support or generation access to the IMO-Controlled Grid should be coordinated closely between the transmitter and the generators involved. The analysis highlighted a few outages with this potential impact. In addition, the impacts of some forced outages have been noted.

System voltage concerns during times of extreme summer peak demands, will limit the flexibility for planning outages in the Toronto and Windsor areas in 2001.

Restoration of the reactive power output capability of Darlington and Pickering units could reduce the stated voltage concerns in the Toronto area.

**Appendix A – Electricity Demand Forecast Details**

**List of Tables**


Table A1 Electricity Demand Forecast..... 3

Table A2 Actual & Forecast Summer and Winter 20-Minute System Peak Demand ..... 5

**List of Figures**

Figure A1 – Transmission Zones Used to Derive the Peak Demand Forecasts ..... 2

**Figure A1 – Transmission Zones Used to Derive the Peak Demand Forecasts**



**Table A1 Electricity Demand Forecast**

| Week Ending Day | 20-Minute Peak Demand by Transmission Zone – Normal Weather Conditions - MW |           |      |      |         |           |         |       |      | Total System 20-min. Peak Demand MW – Various Weather |                                              |                              |
|-----------------|-----------------------------------------------------------------------------|-----------|------|------|---------|-----------|---------|-------|------|-------------------------------------------------------|----------------------------------------------|------------------------------|
|                 | Northwest                                                                   | Northeast | East | Essa | Toronto | Southwest | Niagara | Bruce | West | Normal Weather <sup>1</sup>                           | Normal +1 Standard Dev. Weather <sup>2</sup> | Extreme Weather <sup>3</sup> |
| 8-Oct-00        | 974                                                                         | 1606      | 3227 | 798  | 5450    | 3659      | 803     | 344   | 2121 | 18980                                                 | 19417                                        | 19854                        |
| 15-Oct-00       | 974                                                                         | 1611      | 3237 | 800  | 5466    | 3670      | 806     | 345   | 2128 | 19037                                                 | 19499                                        | 19961                        |
| 22-Oct-00       | 974                                                                         | 1647      | 3308 | 818  | 5586    | 3751      | 823     | 353   | 2175 | 19434                                                 | 19926                                        | 20418                        |
| 29-Oct-00       | 974                                                                         | 1662      | 3339 | 825  | 5639    | 3786      | 831     | 356   | 2195 | 19605                                                 | 20124                                        | 20643                        |
| 5-Nov-00        | 1048                                                                        | 1717      | 3449 | 853  | 5825    | 3911      | 859     | 368   | 2268 | 20297                                                 | 20869                                        | 21441                        |
| 12-Nov-00       | 1048                                                                        | 1771      | 3558 | 879  | 6008    | 4034      | 886     | 379   | 2339 | 20901                                                 | 21459                                        | 22017                        |
| 19-Nov-00       | 1048                                                                        | 1801      | 3618 | 894  | 6109    | 4102      | 901     | 386   | 2378 | 21237                                                 | 21712                                        | 22187                        |
| 26-Nov-00       | 1048                                                                        | 1818      | 3652 | 903  | 6169    | 4141      | 909     | 389   | 2401 | 21427                                                 | 21984                                        | 22541                        |
| 3-Dec-00        | 1101                                                                        | 1841      | 3698 | 914  | 6244    | 4193      | 920     | 394   | 2431 | 21736                                                 | 22361                                        | 22986                        |
| 10-Dec-00       | 1101                                                                        | 1747      | 3925 | 1139 | 6576    | 4243      | 931     | 126   | 2281 | 22069                                                 | 22837                                        | 23605                        |
| 17-Dec-00       | 1101                                                                        | 1768      | 3974 | 1153 | 6656    | 4296      | 943     | 127   | 2309 | 22327                                                 | 23081                                        | 23835                        |
| 24-Dec-00       | 1101                                                                        | 1787      | 4016 | 1165 | 6729    | 4342      | 953     | 129   | 2334 | 22556                                                 | 23394                                        | 24232                        |
| 31-Dec-00       | 1101                                                                        | 1723      | 3873 | 1123 | 6488    | 4187      | 919     | 124   | 2251 | 21790                                                 | 22587                                        | 23384                        |
| 7-Jan-01        | 1080                                                                        | 1745      | 3943 | 1155 | 6677    | 4274      | 938     | 127   | 2295 | 22235                                                 | 23029                                        | 23823                        |
| 14-Jan-01       | 1080                                                                        | 1775      | 4011 | 1175 | 6790    | 4347      | 954     | 129   | 2334 | 22596                                                 | 23478                                        | 24360                        |
| 21-Jan-01       | 1080                                                                        | 1778      | 4017 | 1177 | 6803    | 4355      | 956     | 129   | 2338 | 22632                                                 | 23624                                        | 24616                        |
| 28-Jan-01       | 1080                                                                        | 1756      | 3968 | 1162 | 6718    | 4301      | 944     | 128   | 2310 | 22367                                                 | 23249                                        | 24131                        |
| 4-Feb-01        | 1080                                                                        | 1753      | 3962 | 1160 | 6708    | 4294      | 943     | 128   | 2306 | 22333                                                 | 23100                                        | 23867                        |
| 11-Feb-01       | 1063                                                                        | 1746      | 3945 | 1156 | 6679    | 4276      | 939     | 127   | 2296 | 22227                                                 | 22957                                        | 23687                        |
| 18-Feb-01       | 1063                                                                        | 1726      | 3899 | 1142 | 6601    | 4226      | 928     | 125   | 2269 | 21979                                                 | 22774                                        | 23569                        |
| 25-Feb-01       | 1063                                                                        | 1696      | 3831 | 1122 | 6487    | 4153      | 912     | 123   | 2230 | 21618                                                 | 22420                                        | 23222                        |
| 4-Mar-01        | 1063                                                                        | 1679      | 3794 | 1111 | 6424    | 4112      | 903     | 122   | 2208 | 21415                                                 | 22160                                        | 22905                        |
| 11-Mar-01       | 1007                                                                        | 1658      | 3745 | 1097 | 6341    | 4060      | 891     | 121   | 2180 | 21100                                                 | 21835                                        | 22570                        |
| 18-Mar-01       | 1007                                                                        | 1634      | 3693 | 1082 | 6252    | 4003      | 879     | 119   | 2149 | 20818                                                 | 21555                                        | 22292                        |
| 25-Mar-01       | 1007                                                                        | 1612      | 3642 | 1067 | 6166    | 3948      | 867     | 117   | 2120 | 20545                                                 | 21152                                        | 21759                        |
| 1-Apr-01        | 1007                                                                        | 1582      | 3574 | 1047 | 6053    | 3874      | 850     | 115   | 2081 | 20183                                                 | 20802                                        | 21421                        |
| 8-Apr-01        | 978                                                                         | 1671      | 3375 | 841  | 5757    | 3837      | 842     | 361   | 2221 | 19884                                                 | 20480                                        | 21076                        |
| 15-Apr-01       | 978                                                                         | 1645      | 3321 | 828  | 5666    | 3776      | 829     | 355   | 2186 | 19584                                                 | 20192                                        | 20800                        |
| 22-Apr-01       | 978                                                                         | 1592      | 3214 | 801  | 5483    | 3655      | 802     | 344   | 2116 | 18985                                                 | 19482                                        | 19979                        |
| 29-Apr-01       | 978                                                                         | 1587      | 3206 | 799  | 5468    | 3645      | 800     | 343   | 2110 | 18936                                                 | 19457                                        | 19978                        |
| 6-May-01        | 978                                                                         | 1575      | 3181 | 793  | 5428    | 3617      | 794     | 340   | 2094 | 18798                                                 | 19207                                        | 19616                        |
| 13-May-01       | 924                                                                         | 1568      | 3166 | 789  | 5400    | 3599      | 790     | 339   | 2084 | 18659                                                 | 19160                                        | 19661                        |
| 20-May-01       | 924                                                                         | 1572      | 3175 | 792  | 5416    | 3610      | 792     | 340   | 2090 | 18711                                                 | 19428                                        | 20145                        |
| 27-May-01       | 924                                                                         | 1569      | 3167 | 790  | 5403    | 3601      | 791     | 339   | 2085 | 18669                                                 | 19587                                        | 20505                        |
| 3-Jun-01        | 937                                                                         | 1600      | 3232 | 806  | 5513    | 3674      | 807     | 346   | 2127 | 19042                                                 | 20073                                        | 21104                        |
| 10-Jun-01       | 937                                                                         | 1256      | 3596 | 874  | 6025    | 3906      | 857     | 150   | 2134 | 19735                                                 | 20966                                        | 22197                        |
| 17-Jun-01       | 937                                                                         | 1295      | 3708 | 901  | 6212    | 4027      | 884     | 155   | 2200 | 20319                                                 | 21691                                        | 23063                        |
| 24-Jun-01       | 937                                                                         | 1312      | 3757 | 913  | 6295    | 4081      | 896     | 157   | 2229 | 20576                                                 | 21978                                        | 23380                        |
| 1-Jul-01        | 937                                                                         | 1318      | 3776 | 918  | 6326    | 4101      | 900     | 158   | 2240 | 20675                                                 | 22020                                        | 23365                        |
| 8-Jul-01        | 947                                                                         | 1351      | 3869 | 941  | 6483    | 4203      | 923     | 162   | 2296 | 21174                                                 | 22527                                        | 23880                        |
| 15-Jul-01       | 947                                                                         | 1390      | 3981 | 968  | 6669    | 4324      | 949     | 166   | 2362 | 21756                                                 | 23005                                        | 24254                        |
| 22-Jul-01       | 947                                                                         | 1390      | 3982 | 968  | 6672    | 4325      | 949     | 167   | 2362 | 21760                                                 | 22965                                        | 24170                        |
| 29-Jul-01       | 947                                                                         | 1376      | 3941 | 958  | 6603    | 4281      | 940     | 165   | 2338 | 21548                                                 | 22721                                        | 23894                        |
| 5-Aug-01        | 951                                                                         | 1353      | 3876 | 942  | 6494    | 4210      | 924     | 162   | 2300 | 21211                                                 | 22340                                        | 23469                        |

<sup>1</sup> The values shown are under 'normal' conditions which covers 50% of time weather conditions in that week from a normal distribution of the demand in that week. (This bell curve is used in the calculation of the generation reserve requirement in each week.) Total demand may not match the sum of the zones due to rounding.

<sup>2</sup> The values shown are under 'normal plus one standard deviation' conditions which covers 84.1% of time weather conditions in that week. Such a demand could be expected to occur on some days over a season. The maximum value over a season is provided to the Northeast Power Coordinating Council for seasonal assessments.

<sup>3</sup> The values shown are under 'normal plus two standard deviations' conditions which covers 97.7% of time conditions in that week. Such values are used to assess the adequacy of the transmission system.

| Week Ending Day | 20-Minute Peak Demand by Transmission Zone – Normal Weather Conditions - MW |           |      |      |         |           |         |       |      |  | Total System 20-min. Peak Demand MW – Various Weather |                                                 |                              |
|-----------------|-----------------------------------------------------------------------------|-----------|------|------|---------|-----------|---------|-------|------|--|-------------------------------------------------------|-------------------------------------------------|------------------------------|
|                 | Northwest                                                                   | Northeast | East | Essa | Toronto | Southwest | Niagara | Bruce | West |  | Normal Weather <sup>1</sup>                           | Normal +1 Standard Dev.<br>Weather <sup>2</sup> | Extreme Weather <sup>3</sup> |
| 12-Aug-01       | 951                                                                         | 1331      | 3812 | 927  | 6386    | 4140      | 909     | 159   | 2262 |  | 20877                                                 | 21916                                           | 22955                        |
| 19-Aug-01       | 951                                                                         | 1331      | 3811 | 926  | 6384    | 4139      | 909     | 159   | 2261 |  | 20870                                                 | 21955                                           | 23040                        |
| 26-Aug-01       | 951                                                                         | 1319      | 3777 | 918  | 6328    | 4103      | 901     | 158   | 2241 |  | 20696                                                 | 21881                                           | 23066                        |
| 2-Sep-01        | 956                                                                         | 1311      | 3756 | 913  | 6292    | 4079      | 895     | 157   | 2228 |  | 20588                                                 | 21838                                           | 23088                        |
| 9-Sep-01        | 958                                                                         | 1251      | 3582 | 871  | 6001    | 3891      | 854     | 150   | 2125 |  | 19682                                                 | 20802                                           | 21922                        |
| 16-Sep-01       | 958                                                                         | 1236      | 3540 | 860  | 5931    | 3845      | 844     | 148   | 2100 |  | 19462                                                 | 20449                                           | 21436                        |
| 23-Sep-01       | 958                                                                         | 1211      | 3468 | 843  | 5811    | 3767      | 827     | 145   | 2058 |  | 19088                                                 | 19909                                           | 20730                        |
| 30-Sep-01       | 958                                                                         | 1199      | 3433 | 834  | 5752    | 3729      | 819     | 144   | 2037 |  | 18904                                                 | 19427                                           | 19950                        |
| 7-Oct-01        | 974                                                                         | 1602      | 3235 | 806  | 5518    | 3678      | 807     | 346   | 2129 |  | 19095                                                 | 19531                                           | 19967                        |
| 14-Oct-01       | 974                                                                         | 1618      | 3266 | 814  | 5572    | 3714      | 815     | 350   | 2150 |  | 19273                                                 | 19713                                           | 20153                        |
| 21-Oct-01       | 974                                                                         | 1641      | 3314 | 826  | 5654    | 3768      | 827     | 355   | 2182 |  | 19541                                                 | 20054                                           | 20567                        |
| 28-Oct-01       | 974                                                                         | 1659      | 3350 | 835  | 5716    | 3809      | 836     | 359   | 2205 |  | 19744                                                 | 20259                                           | 20774                        |
| 4-Nov-01        | 1048                                                                        | 1692      | 3417 | 852  | 5830    | 3885      | 853     | 366   | 2250 |  | 20193                                                 | 20724                                           | 21255                        |
| 11-Nov-01       | 1048                                                                        | 1759      | 3552 | 885  | 6059    | 4038      | 886     | 380   | 2338 |  | 20946                                                 | 21509                                           | 22072                        |
| 18-Nov-01       | 1048                                                                        | 1791      | 3616 | 902  | 6169    | 4112      | 903     | 387   | 2381 |  | 21308                                                 | 21815                                           | 22322                        |
| 25-Nov-01       | 1048                                                                        | 1810      | 3656 | 911  | 6237    | 4156      | 912     | 391   | 2406 |  | 21527                                                 | 22051                                           | 22575                        |
| 2-Dec-01        | 1082                                                                        | 1831      | 3697 | 922  | 6306    | 4203      | 923     | 396   | 2433 |  | 21791                                                 | 22413                                           | 23035                        |
| 9-Dec-01        | 1107                                                                        | 1738      | 3927 | 1150 | 6648    | 4256      | 934     | 126   | 2286 |  | 22173                                                 | 22880                                           | 23587                        |
| 16-Dec-01       | 1107                                                                        | 1763      | 3983 | 1167 | 6744    | 4317      | 948     | 128   | 2318 |  | 22475                                                 | 23226                                           | 23977                        |
| 23-Dec-01       | 1107                                                                        | 1783      | 4028 | 1180 | 6821    | 4366      | 958     | 130   | 2344 |  | 22715                                                 | 23533                                           | 24351                        |
| 30-Dec-01       | 1107                                                                        | 1706      | 3855 | 1129 | 6527    | 4179      | 917     | 124   | 2244 |  | 21788                                                 | 22586                                           | 23384                        |
| 6-Jan-02        | 1107                                                                        | 1754      | 3983 | 1177 | 6810    | 4328      | 950     | 131   | 2323 |  | 22555                                                 | 23356                                           | 24157                        |
| 13-Jan-02       | 1081                                                                        | 1775      | 4029 | 1191 | 6880    | 4378      | 961     | 132   | 2350 |  | 22778                                                 | 23613                                           | 24448                        |
| 20-Jan-02       | 1081                                                                        | 1780      | 4041 | 1195 | 6901    | 4391      | 964     | 133   | 2356 |  | 22840                                                 | 23827                                           | 24814                        |
| 27-Jan-02       | 1081                                                                        | 1761      | 3998 | 1182 | 6827    | 4345      | 954     | 131   | 2332 |  | 22611                                                 | 23548                                           | 24485                        |
| 3-Feb-02        | 1081                                                                        | 1757      | 3988 | 1179 | 6809    | 4333      | 951     | 131   | 2326 |  | 22555                                                 | 23364                                           | 24173                        |
| 10-Feb-02       | 1063                                                                        | 1742      | 3954 | 1169 | 6751    | 4297      | 943     | 130   | 2306 |  | 22354                                                 | 23099                                           | 23844                        |
| 17-Feb-02       | 1063                                                                        | 1728      | 3923 | 1160 | 6699    | 4263      | 936     | 129   | 2288 |  | 22189                                                 | 22960                                           | 23731                        |
| 24-Feb-02       | 1063                                                                        | 1696      | 3851 | 1139 | 6576    | 4185      | 919     | 127   | 2246 |  | 21801                                                 | 22654                                           | 23507                        |
| 3-Mar-02        | 1063                                                                        | 1683      | 3820 | 1129 | 6524    | 4151      | 911     | 125   | 2228 |  | 21634                                                 | 22379                                           | 23124                        |
| 10-Mar-02       | 1007                                                                        | 1660      | 3769 | 1114 | 6436    | 4096      | 899     | 124   | 2198 |  | 21302                                                 | 22045                                           | 22788                        |
| 17-Mar-02       | 1007                                                                        | 1639      | 3722 | 1100 | 6355    | 4044      | 888     | 122   | 2170 |  | 21048                                                 | 21795                                           | 22542                        |
| 24-Mar-02       | 1007                                                                        | 1612      | 3659 | 1082 | 6249    | 3977      | 873     | 120   | 2134 |  | 20713                                                 | 21314                                           | 21915                        |
| 31-Mar-02       | 1007                                                                        | 1583      | 3595 | 1063 | 6138    | 3906      | 858     | 118   | 2096 |  | 20365                                                 | 21028                                           | 21691                        |

**Table A2 Actual & Forecast Summer and Winter 20-Minute System Peak Demand**

| Year              | Summer Peak Demand (MW) | Winter Peak Demand (MW) | Summer Peak Demand / Winter Peak Demand Ratio |
|-------------------|-------------------------|-------------------------|-----------------------------------------------|
| 1990              | 20,453                  | 22,311                  | 0.917                                         |
| 1991              | 21,150                  | 23,212                  | 0.911                                         |
| 1992              | 19,857                  | 23,487                  | 0.845                                         |
| 1993              | 20,806                  | 21,951                  | 0.948                                         |
| 1994              | 20,923                  | 24,007                  | 0.872                                         |
| 1995              | 21,766                  | 22,855                  | 0.952                                         |
| 1996              | 21,428                  | 22,321                  | 0.960                                         |
| 1997              | 21,667                  | 22,197                  | 0.976                                         |
| 1998              | 22,443                  | 22,067                  | 1.017                                         |
| 1999              | 23,435                  | 23,308                  | 1.005                                         |
| 2000              | 23,222                  | 23,428                  | 0.991                                         |
| 2001 <sup>1</sup> | 21,761 (f)              | 22,633 (f)              | 0.961                                         |
| 2002 <sup>2</sup> | 22,088 (f)              | 22,841 (f)              | 0.967                                         |

(f) = forecast

<sup>1</sup> The forecast is based on normal weather.<sup>2</sup> The summer 2002 peak is not within the scope of this forecast. This estimate is provided in order to illustrate the relative changes in summer and winter peak

Appendix B – Ontario Electricity System – Maps

List of Figures

Figure B1.1 – Southern Ontario ..... 2

Figure B1.2 – Northern Ontario ..... 2

Figure B2.1 – GTA ..... 3

Figure B2.2 – Hamilton..... 3

Figure B2.3 – Niagara ..... 4

Figure B2.4 – Sarnia ..... 4

Figure B2.5 – Windsor..... 5

Figure B2.6 – Thunder Bay ..... 5

Figure B2.7 – Ottawa ..... 6

Figure B2.8 – London..... 6

Figure B2.9 – Sudbury ..... 7


Figure B2.10 – Timmins ..... 7

## 1.0 The Ontario Electricity System 230 & 500 kV Geographical Layout Map<sup>1</sup>

Figure B1.1 – Southern Ontario



Figure B1.2 – Northern Ontario



<sup>1</sup> Maps are provided with the permission of Hydro One Networks Inc.

## 2.0 Load Centres

Figure B2.1 – GTA




Figure B2.2 – Hamilton




Figure B2.3 – Niagara




Figure B2.4 – Sarnia




Figure B2.5 – Windsor




Figure B2.6 – Thunder Bay




Figure B2.7 – Ottawa




Figure B2.8 – London




Figure B2.9 – Sudbury





Figure B2.10 – Timmins



## Appendix C – System Resources Details

### Table of Contents

|            |                                                 |          |
|------------|-------------------------------------------------|----------|
| <b>1.0</b> | <b>Resources Data Tables .....</b>              | <b>2</b> |
| <b>2.0</b> | <b>Generation Reserve Requirement .....</b>     | <b>4</b> |
| 2.1        | Method.....                                     | 4        |
| 2.2        | Demand Forecast Uncertainty due to Weather..... | 4        |
| 2.3        | Resource Representation.....                    | 5        |
| 2.4        | Representation of Interconnected Systems .....  | 5        |
| 2.5        | Transmission Systems .....                      | 5        |
| 2.6        | Study Procedures.....                           | 5        |

### List of Tables

|                                                                       |   |
|-----------------------------------------------------------------------|---|
| Table C1.1 Ontario Power Generation Inc. Power Stations in Study..... | 2 |
| Table C1.2 Ontario Power Generation Inc. Units Not In Study.....      | 3 |
| Table C1.3 Contract Generators Power Stations in Study.....           | 3 |
| Table C1.4 Contract Generators Small Power Stations in Study.....     | 3 |
| Table C2.1 Assessment of Gross Margin .....                           | 6 |

### List of Figures

|                                                                     |   |
|---------------------------------------------------------------------|---|
| Figure C2.1 Weekly Demand Forecast Uncertainty due to Weather ..... | 4 |
|---------------------------------------------------------------------|---|

## 1.0 Resources Data Tables

**Table C1.1 Ontario Power Generation Inc. Power Stations in Study**

| Name                       | Resource Type | Declared Net Capacity (MW) | Units | Name                       | Resource Type | Declared Net Capacity (MW) | Units |
|----------------------------|---------------|----------------------------|-------|----------------------------|---------------|----------------------------|-------|
| Bruce B                    | Nuclear       | 3,140                      | 4     | Des Joachims               | Hydro         | 429                        | 8     |
| Darlington                 | Nuclear       | 3,524                      | 4     | Ear Falls                  | Hydro         | 17                         | 4     |
| Pickering A                | Nuclear       | 2,060                      | 4     | G.W. Rayner                | Hydro         | 46                         | 2     |
| Pickering B                | Nuclear       | 2,064                      | 4     | Harmon                     | Hydro         | 141                        | 2     |
| Atikokan                   | Coal          | 215                        | 1     | Kakabeka Falls             | Hydro         | 25                         | 4     |
| Lakeview                   | Coal          | 1,140                      | 4     | Kipling                    | Hydro         | 141                        | 2     |
| Lambton                    | Coal          | 1,975                      | 4     | Little Long                | Hydro         | 133                        | 2     |
| Lennox                     | Oil & Gas     | 2,140                      | 4     | Lower Notch                | Hydro         | 274                        | 2     |
| Nanticoke                  | Coal          | 3,920                      | 8     | Manitou Falls              | Hydro         | 66                         | 5     |
| Thunder Bay                | Coal          | 310                        | 2     | Mountain Chute             | Hydro         | 170                        | 2     |
| CTU's                      | Oil & Gas     | 22                         | 5     | Otter Rapids               | Hydro         | 182                        | 4     |
| Tacke Turbine              | Wind          | 1                          | 1     | Otto Holden                | Hydro         | 243                        | 8     |
| Abitibi Canyon             | Hydro         | 314                        | 5     | Pine Portage               | Hydro         | 131                        | 4     |
| Aguasabon                  | Hydro         | 46                         | 2     | R.H. Saunders              | Hydro         | 1,005                      | 16    |
| Alexander                  | Hydro         | 67                         | 5     | Red Rock Falls             | Hydro         | 41                         | 2     |
| Arnprior                   | Hydro         | 82                         | 2     | Silver Falls               | Hydro         | 48                         | 1     |
| Aubrey Falls               | Hydro         | 162                        | 2     | Sir Adam Beck 1            | Hydro         | 496                        | 10    |
| Barrett Chute              | Hydro         | 176                        | 4     | Sir Adam Beck 2            | Hydro         | 1,360                      | 16    |
| Cameron Falls              | Hydro         | 78                         | 7     | Sir Adam Beck PGS          | Hydro         | 174                        | 6     |
| Caribou Falls              | Hydro         | 87                         | 3     | Smoky Falls                | Hydro         | 56                         | 4     |
| Chats Falls <sup>(1)</sup> | Hydro         | 96                         | 4     | Stewartville               | Hydro         | 182                        | 5     |
| Chenault                   | Hydro         | 139                        | 8     | Wells                      | Hydro         | 232                        | 2     |
| Decew Falls 1              | Hydro         | 23                         | 4     | Whitedog Falls             | Hydro         | 68                         | 3     |
| Decew Falls 2              | Hydro         | 144                        | 2     | Other Hydro <sup>(2)</sup> | Hydro         | 206                        | 86    |

<sup>(1)</sup> Capacity and units shown are for Ontario half of the station.

<sup>(2)</sup> They include plants with station capacity of less than 15 MW (156 MW) and 50 MW of hydro unit upgrades completed in year 2000.

**Table C1.2 Ontario Power Generation Inc. Units Not In Study**

| <b>Name</b>                           | <b>Capacity (MW)</b> |
|---------------------------------------|----------------------|
| Bruce A 1, 2, 3, 4 (Nuclear) (OS)     | 3,076                |
| Lakeview Units 3, 4, 7, 8 (Coal) (RE) | 1,138                |
| Thunder Bay 1 (Coal) (RE)             | 94                   |

**Notes:**

OS On long term scheduled maintenance or Forced Outage. Not available to operate (greater than 3 months)

RE Retired (no longer in service and not expected to be returned to service)

**Table C1.3 Contract Generators Power Stations in Study**

| <b>Resource Type</b>                                            | <b>In-Service Capacity (MW)</b> |
|-----------------------------------------------------------------|---------------------------------|
| Natural Gas                                                     | 1,038                           |
| Natural Gas/ Black Liquor                                       | 103                             |
| Landfill Gas                                                    | 57                              |
| Natural Gas/ Waste Heat                                         | 328                             |
| Hydro                                                           | 75                              |
| Municipal Solid Waste                                           | 15                              |
| Steam                                                           | 40                              |
| Subtotal (10 MW in size or greater shown above)                 | <b>1,656</b>                    |
| Subtotal (less than 10 MW in size) (See Table C1.4 for Details) | <b>110</b>                      |
| <b>Total</b>                                                    | <b>1,766</b>                    |

**Table C1.4 Contract Generators Small Power Stations in Study**

| <b>Resource Type</b>                                                             | <b>In-Service Capacity (MW)</b> |
|----------------------------------------------------------------------------------|---------------------------------|
| Natural Gas                                                                      | 10                              |
| Landfill Gas                                                                     | 5                               |
| Municipal Solid Waste                                                            | 4                               |
| Wood Waste                                                                       | 17                              |
| Hydro                                                                            | 59                              |
| Waste/ Flare Gas                                                                 | 2                               |
| Subtotal (greater than or equal to 1 MW in size and less than 10 MW shown above) | 97                              |
| Subtotal (less than 1 MW in size) – Mostly Hydro, with some Natural Gas          | 13                              |
| <b>Total</b>                                                                     | <b>110 MW</b>                   |

## 2.0 Generation Reserve Requirement


### 2.1 Method

The IMO uses a Load and Capacity (L&C) model to determine the Generation Reserve Requirements from week to week. The mix of generating plant, generating unit forced outage rates and the demand forecast and the associated uncertainties are inputs to the model. A Generation Adequacy Standard of 0.1 (day/year), is used to determine the Reserve Requirement for each week of the planning year. The adequacy of the available generation facilities to meet the demand over the 18-month study period can be assessed from the forecast weekly Margin, shown in Table C2.1.

### 2.2 Demand Forecast Uncertainty due to Weather

The total energy demand is split into weather and non-weather components. A normal distribution of weather swings, in any week, is provided by input of the associated standard deviation. This data is obtained from 30-year weather statistics and is updated annually. The standard deviation of weather-related demand (Load Forecast Uncertainty or LFU) varies between about 2% and 7 % through the year as shown in Figure C2.1. The peak demand probability distribution in any week is thus available to the L&C program.

**Figure C2.1 Weekly Demand Forecast Uncertainty due to Weather**



## 2.3 Resource Representation

### Unit Ratings

Thermal generating units are assumed to be capable of operating at a level equal to their normal Maximum Continuous Rating (MCR). Hydroelectric system output is based on data provided by the Owners. The peak and energy output of all combustion turbines varies considerably with changes in ambient air temperature and, hence, both summer and winter values are included.

### Forced Outage Rates of Generating Units

Derating-Adjusted Forced outage rates for each unit are used that reflect both forced outages and periods of derated output. Values are provided by Generation Plant Owners.

## 2.4 Representation of Interconnected Systems

There are effectively three systems that can provide assistance to Ontario, namely, USA, Quebec and Manitoba. For this study, interconnection assistance is not included, in the calculation of the Margin but is taken into account in the assessments, whenever a negative margin is indicated.

## 2.5 Transmission Systems

The Ontario IMO Controlled Grid consists of a robust southern grid and a sparse northern grid. The southern grid has few binding limits and these have been accounted for in this study. The northwestern part of the northern grid has limitations that potentially constrain generation capacity. Some 25-hz generation in the southern grid is bottled by frequency changer capability. Total generation limitations are modeled as a reduction in capability of up to 320 MW.

## 2.6 Study Procedures

For the 18-month assessment period, an LOLP value of 0.1 days per year was utilized to determine the Required Reserve in each week of the year. The uncertainty in the demand forecast varies from week to week, and the available generation mix may also vary, giving rise to a different Reserve Requirement for the Peak hour of each week. The risk is thus level throughout the year when calculating the Margin. Capacity available above the Reserve Requirement and Demand is considered to be surplus in any week and may be released for planned outages.

**Table C2.1 Assessment of Gross Margin**

| <b>Week Ending Day</b> | <b>Total Declared Net Capacity, MW</b> | <b>Primary Demand, MW</b> | <b>Generation Reserve Req. MW</b> | <b>Generation Reserve Req. %</b> | <b>Gross<sup>1</sup> Margin MW</b> |
|------------------------|----------------------------------------|---------------------------|-----------------------------------|----------------------------------|------------------------------------|
| 08-Oct-00              | 30590                                  | 18980                     | 2816                              | 14.8                             | 8794                               |
| 15-Oct-00              | 30590                                  | 19037                     | 2809                              | 14.8                             | 8744                               |
| 22-Oct-00              | 30590                                  | 19434                     | 2938                              | 15.1                             | 8218                               |
| 29-Oct-00              | 30590                                  | 19605                     | 2951                              | 15.1                             | 8034                               |
| 05-Nov-00              | 30590                                  | 20297                     | 3066                              | 15.1                             | 7227                               |
| 12-Nov-00              | 30590                                  | 20901                     | 3117                              | 14.9                             | 6572                               |
| 19-Nov-00              | 30590                                  | 21237                     | 3065                              | 14.4                             | 6288                               |
| 26-Nov-00              | 30590                                  | 21427                     | 3209                              | 15.0                             | 5954                               |
| 03-Dec-00              | 30590                                  | 21736                     | 3278                              | 15.1                             | 5576                               |
| 10-Dec-00              | 30590                                  | 22069                     | 3381                              | 15.3                             | 5140                               |
| 17-Dec-00              | 30590                                  | 22327                     | 3403                              | 15.2                             | 4860                               |
| 24-Dec-00              | 30590                                  | 22556                     | 3522                              | 15.6                             | 4512                               |
| 31-Dec-00              | 30590                                  | 21790                     | 3410                              | 15.6                             | 5390                               |
| 07-Jan-01              | 29790                                  | 22235                     | 3298                              | 14.8                             | 4257                               |
| 14-Jan-01              | 29790                                  | 22596                     | 3409                              | 15.1                             | 3785                               |
| 21-Jan-01              | 29790                                  | 22632                     | 3526                              | 15.6                             | 3632                               |
| 28-Jan-01              | 29790                                  | 22367                     | 3390                              | 15.2                             | 4033                               |
| 04-Feb-01              | 29790                                  | 22333                     | 3279                              | 14.7                             | 4178                               |
| 11-Feb-01              | 29790                                  | 22227                     | 3207                              | 14.4                             | 4356                               |
| 18-Feb-01              | 29790                                  | 21979                     | 3247                              | 14.8                             | 4564                               |
| 25-Feb-01              | 29790                                  | 21618                     | 3239                              | 15.0                             | 4933                               |
| 04-Mar-01              | 29790                                  | 21415                     | 3207                              | 15.0                             | 5168                               |
| 11-Mar-01              | 29790                                  | 21100                     | 3209                              | 15.2                             | 5481                               |
| 18-Mar-01              | 29790                                  | 20818                     | 3207                              | 15.4                             | 5765                               |
| 25-Mar-01              | 29790                                  | 20545                     | 3060                              | 14.9                             | 6185                               |
| 01-Apr-01              | 29790                                  | 20183                     | 2959                              | 14.7                             | 6648                               |
| 08-Apr-01              | 29790                                  | 19884                     | 2989                              | 15.0                             | 6917                               |
| 15-Apr-01              | 29790                                  | 19584                     | 2872                              | 14.7                             | 7334                               |
| 22-Apr-01              | 29790                                  | 18985                     | 2696                              | 14.2                             | 8109                               |
| 29-Apr-01              | 29790                                  | 18936                     | 2773                              | 14.6                             | 8081                               |
| 06-May-01              | 29790                                  | 18798                     | 2701                              | 14.4                             | 8291                               |
| 13-May-01              | 29790                                  | 18659                     | 2602                              | 13.9                             | 8529                               |
| 20-May-01              | 29790                                  | 18711                     | 2747                              | 14.7                             | 8332                               |
| 27-May-01              | 29790                                  | 18669                     | 3092                              | 16.6                             | 8029                               |
| 03-Jun-01              | 29790                                  | 19042                     | 3405                              | 17.9                             | 7343                               |
| 10-Jun-01              | 29790                                  | 19735                     | 3615                              | 18.3                             | 6440                               |
| 17-Jun-01              | 29790                                  | 20319                     | 3783                              | 18.6                             | 5688                               |
| 24-Jun-01              | 29790                                  | 20576                     | 3865                              | 18.8                             | 5349                               |
| 01-Jul-01              | 29790                                  | 20675                     | 3786                              | 18.3                             | 5329                               |
| 08-Jul-01              | 29790                                  | 21174                     | 3793                              | 17.9                             | 4823                               |
| 15-Jul-01              | 29790                                  | 21756                     | 3737                              | 17.2                             | 4297                               |
| 22-Jul-01              | 29790                                  | 21760                     | 3694                              | 17.0                             | 4336                               |
| 29-Jul-01              | 29790                                  | 21548                     | 3616                              | 16.8                             | 4626                               |
| 05-Aug-01              | 29790                                  | 21211                     | 3551                              | 16.7                             | 5028                               |
| 12-Aug-01              | 29790                                  | 20877                     | 3466                              | 16.6                             | 5447                               |
| 19-Aug-01              | 29790                                  | 20870                     | 3511                              | 16.8                             | 5409                               |
| 26-Aug-01              | 29790                                  | 20696                     | 3614                              | 17.5                             | 5480                               |

| Week Ending Day | Total Declared Net Capacity, MW | Primary Demand, MW | Generation Reserve Req. MW | Generation Reserve Req. % | Gross <sup>1</sup> Margin MW |
|-----------------|---------------------------------|--------------------|----------------------------|---------------------------|------------------------------|
| 02-Sep-01       | 29790                           | 20588              | 3694                       | 17.9                      | 5508                         |
| 09-Sep-01       | 29790                           | 19682              | 3324                       | 16.9                      | 6784                         |
| 16-Sep-01       | 29790                           | 19462              | 3253                       | 16.7                      | 7075                         |
| 23-Sep-01       | 29790                           | 19088              | 3033                       | 15.9                      | 7669                         |
| 30-Sep-01       | 29790                           | 18904              | 2691                       | 14.2                      | 8195                         |
| 07-Oct-01       | 29790                           | 19095              | 2673                       | 14.0                      | 8022                         |
| 14-Oct-01       | 29790                           | 19273              | 2723                       | 14.1                      | 7794                         |
| 21-Oct-01       | 29790                           | 19541              | 2865                       | 14.7                      | 7384                         |
| 28-Oct-01       | 29790                           | 19744              | 2897                       | 14.7                      | 7149                         |
| 04-Nov-01       | 29790                           | 20193              | 2878                       | 14.3                      | 6719                         |
| 11-Nov-01       | 29790                           | 20946              | 3114                       | 14.9                      | 5730                         |
| 18-Nov-01       | 29790                           | 21308              | 3121                       | 14.6                      | 5361                         |
| 25-Nov-01       | 29790                           | 21527              | 3163                       | 14.7                      | 5100                         |
| 02-Dec-01       | 29790                           | 21791              | 3159                       | 14.5                      | 4840                         |
| 09-Dec-01       | 29790                           | 22173              | 3306                       | 14.9                      | 4311                         |
| 16-Dec-01       | 29790                           | 22475              | 3384                       | 15.1                      | 3931                         |
| 23-Dec-01       | 29790                           | 22715              | 3471                       | 15.3                      | 3604                         |
| 30-Dec-01       | 29790                           | 21788              | 3248                       | 14.9                      | 4754                         |
| 06-Jan-02       | 29790                           | 22555              | 3426                       | 15.2                      | 3809                         |
| 13-Jan-02       | 29790                           | 22778              | 3497                       | 15.4                      | 3515                         |
| 20-Jan-02       | 29790                           | 22840              | 3683                       | 16.1                      | 3267                         |
| 27-Jan-02       | 29790                           | 22611              | 3582                       | 15.8                      | 3597                         |
| 03-Feb-02       | 29790                           | 22555              | 3519                       | 15.6                      | 3716                         |
| 10-Feb-02       | 29790                           | 22354              | 3388                       | 15.2                      | 4048                         |
| 17-Feb-02       | 29790                           | 22189              | 3336                       | 15.0                      | 4265                         |
| 24-Feb-02       | 29790                           | 21801              | 3386                       | 15.5                      | 4603                         |
| 03-Mar-02       | 29790                           | 21634              | 3287                       | 15.2                      | 4869                         |
| 10-Mar-02       | 29790                           | 21302              | 3168                       | 14.9                      | 5320                         |
| 17-Mar-02       | 29790                           | 21048              | 3185                       | 15.1                      | 5557                         |
| 24-Mar-02       | 29790                           | 20713              | 3038                       | 14.7                      | 6039                         |
| 31-Mar-02       | 29790                           | 20365              | 3013                       | 14.8                      | 6412                         |

<sup>1</sup> Gross Margin = Total Declared Net Capacity – Primary Demand – Generation Reserve Requirement. This quantity does not account for forced or planned outages for generation resources.

## Appendix D – Transmission System Details

### Table of Contents

|            |                                                                               |           |
|------------|-------------------------------------------------------------------------------|-----------|
| <b>1.0</b> | <b>Transmission System Description.....</b>                                   | <b>2</b>  |
| 1.1        | Transmission System Interfaces.....                                           | 2         |
| 1.2        | Interface Characteristics .....                                               | 3         |
| 1.3        | Transmission System Zones.....                                                | 7         |
| 1.4        | Transmission System Interconnections' Capabilities and External Markets ..... | 8         |
| <b>2.0</b> | <b>Definitions and Limits of Ontario's Interfaces .....</b>                   | <b>11</b> |
| 2.1        | Definitions of Ontario's Interfaces.....                                      | 11        |
| 2.2        | Limits of Ontario's Interfaces .....                                          | 13        |
| <b>3.0</b> | <b>Definitions and Limits of Ontario's Interconnections .....</b>             | <b>14</b> |
| 3.1        | Definitions of Ontario's Interconnections .....                               | 14        |
| 3.2        | Limits of Ontario's Interconnections.....                                     | 15        |
| <b>4.0</b> | <b>Plans – Hydro One .....</b>                                                | <b>17</b> |
| <b>5.0</b> | <b>Planned Transmission Outages.....</b>                                      | <b>18</b> |

### List of Tables

|                                                          |    |
|----------------------------------------------------------|----|
| Table D2.1 Ontario's Interface Base Limits .....         | 13 |
| Table D3.1 Ontario's Interconnection Limits.....         | 16 |
| Table D4.1 Committed Plans - Hydro One .....             | 17 |
| Table D5.1 Transmission Outages Northwest Zone.....      | 18 |
| Table D5.3 Transmission Outages Essa Zone .....          | 20 |
| Table D5.4 Transmission Outages Bruce Zone.....          | 21 |
| Table D5.5 Transmission Outages West Zone.....           | 22 |
| Table D5.6 Transmission Outages Niagara Zone .....       | 23 |
| Table D5.7 Transmission Outages South Western Zone ..... | 24 |
| Table D5.8 Transmission Outages Toronto Zone.....        | 25 |
| Table D5.9 Transmission Outages East Zone.....           | 27 |

### List of Figures

|                                                                                         |   |
|-----------------------------------------------------------------------------------------|---|
| Figure D1.1 Ontario's Internal Zones and External Interconnections.....                 | 2 |
| Figure D1.2.1 – Historical Flow Distribution – EWTE/EWTW and FN/FS Interfaces .....     | 4 |
| Figure D1.2.2 – Historical Flow Distribution – BLIP/NBLIP, FETT and QFW Interfaces..... | 6 |


This appendix contains, in Section 1.0, a description of the Ontario Transmission System followed, in Sections 2.0 and 3.0, by Ontario's Interface and Interconnection Definitions and Limits. In Section 4.0 are shown Hydro One's committed transmission facilities addition plans and, in Section 5.0, the transmission outage plan for the studied period is presented along with comments regarding the impact of the outages, where necessary.

## 1.0 Transmission System Description

### 1.1 Transmission System Interfaces

There are eight major interfaces in the Ontario electricity system, which will be accounted for in this study, as illustrated in Figure D1.1.

**Figure D1.1 Ontario's Internal Zones and External Interconnections**



## **Interface Definitions**

Interface definitions are formed by grouping one or more lines for the purpose of measuring their combined flow and enforcing a power flow limit or as it is more commonly called an interface limit. Interface limits are directional and interfaces may have limits imposed in one or both directions. Section 2.1 shows the major interface definitions used in Ontario. Notice that for each individual transmission element included in an interface definition both the positive direction of power flow and measurement point (e.g. which end of a transmission line the power flow is measured at) are specified.

## **Interface Capability Limits**

Section 2.2 shows the base limits for the major interfaces that correspond to the definitions in Section 2.1; only normal system (all transmission elements in-service) limits are shown. Note that some limits are simply constants (e.g. BLIP) and others are more complicated and may depend on parameters such as specific generator unit statuses, other flows, primary demand, etc. (e.g. NBLIP, FETT, FABC). In cases where interface limits are based on thermal capability, separate ratings are shown for summer and winter conditions.

## **1.2 Interface Characteristics**


### **The EWTE/EWTW Interface**

The East-West Transfer East (EWTE) and East-West Transfer West (EWTW) flows are functionally related to the power flows between Ontario and Manitoba (OMTE/OMTW etc.). In this relationship OMTE/OMTW flows can be generally thought of as the independent variables as they are under phase shifter control.

The maximum limits on the East-West tie are 325 MW to the east and 350 MW to the west. The EWTE and EWTW interfaces are constrained by stability limitations. A sample of historical flow distribution on the East West Ties is shown in the Figure D1.2.1.

### **The FN/FS Interface**

The Flow South (FS) limit is 1,400 MW and the Flow North (FN) limit is 1,900 MW. The Flow North and Flow South interfaces are constrained by voltage and stability limits respectively. A sample of historical flow distribution on the Flow North / South interface is shown in the Figure D1.2.1.

**Figure D1.2.1 – Historical Flow Distribution – EWTE/EWTW and FN/FS Interfaces**

**The CLAN/CLAS Interface**

The Claireville North (CLAN) limit is 2,000 MW and the Claireville South (CLAS) limit is 1,000 MW.

**The FABC Interface**

The Flow Away From Bruce Complex (FABC) limit is a functional relationship with a number of other system parameters. With only a total of four Bruce units available (the other four are on indefinite outage) the FABC limit is high enough that it is never limiting. The FABC limit can also be improved through the use of generation rejection of Bruce units.

**The FETT Interface**


The FETT (Flow East Towards Toronto) interface limit is a function of a variety of parameters. Normally the limit is near its high end of about 5,700 MW. The interface is constrained by a combination of stability and thermal limits. There is no limit specified for flows to the west, as the level of flows expected in that direction will not cause system concerns. A sample of historical flow distribution on the FETT interface is shown in the Figure D1.2.2.

**The QFW Interface**

The QFW (Queenston Flow West) interface is limited to 2,000 MW for flows to the west in the winter. In the summer, the limit is 1,800 MW to the west. This interface is constrained by thermal limitations. There is no limit specified for flows to the east, as the level of flows expected in that direction will not cause system concerns. A sample of historical flow distribution on the QFW interface is shown in the Figure D1.2.2.

**The BLIP/NBLIP Interface**

The BLIP (Buchanan Longwood Input) interface is limited to 3,500 MW to the west due to stability limitations. The NBLIP interface limit is a function of a variety of parameters. Normally the limit is near its high end of about 1,500 MW; the interface is typically constrained by voltage limitations. A sample of historical flow distribution on the BLIP interface is shown in the Figure D1.2.2.

**Figure D1.2.2 – Historical Flow Distribution – BLIP/NBLIP, FETT and QFW Interfaces**

**The FWIC Interface**

This interface does not have a pre-defined limit. It is included in this study to provide a boundary for the creation of the East Zone to allow for specific forecasts for this region for such parameters as economic conditions for load growth, total resources, etc.

**1.3 Transmission System Zones**

The Ontario transmission system has been divided up into nine zones to facilitate the study. Zonal boundaries have been chosen to correspond with the interface definitions in Section 2.1.

**Northwest Zone Characteristics**

- The total resources generally exceed the peak primary demand.
- The generation is mainly hydroelectric with some coal
- The zone is externally connected to the Manitoba and Minnesota systems.
- Both interconnections are under phase shifter control.
- MAPP (Mid-Continent Area Power Pool) criteria (similar to NPCC) are observed in Manitoba and Minnesota and there is a plan to move toward MAPP criteria limits in the Northwest zone. For many years Manitoba has accepted Northwest zone limits based on criteria less stringent than MAPP, but recently Manitoba joined the MAPP reliability council and as a result Ontario is compelled accordingly.

**Northeast Zone Characteristics**

- The total resources generally exceed the peak primary demand.
- The generation is mainly hydroelectric with some cogeneration.
- The zone is externally connected to the Quebec grid.
- The interconnection with Quebec is radial.

**Essa Zone Characteristics**

- The total resources are much less than the peak primary demand.
- The generation is totally hydroelectric.
- There are no external interconnections.

**East Zone Characteristics**

- The total resources exceed the peak primary demand.
- The generation is a mix of hydroelectric, oil, and gas.
- The zone is externally connected to the Quebec grid.
- The interconnection with Quebec is radial.
- It is also externally connected to New York with phase shifter control.

**Toronto Zone Characteristics**

- The total resources are much less than the peak primary demand.
- The generation is mostly nuclear and coal.
- There are no external interconnections.

**Bruce Zone Characteristics**

- The total resources are much greater than the peak primary demand.
- The generation is mostly nuclear.
- There are no external interconnections.

**Southwest Zone Characteristics**

- The total resources are well balanced with the peak primary demand.
- The generation is mostly coal.
- There are no external interconnections.

**West Zone Characteristics**

- The total resources are slightly less than the peak primary demand.
- The generation is mostly coal.
- The interconnection with Michigan will be under phase shifter control, by June 2001.

**Niagara Zone Characteristics**

- The total resources are much higher than the peak primary demand.
- The generation is mostly hydroelectric.
- There is a free-flowing interconnection with New York.

**1.4 Transmission System Interconnections' Capabilities and External Markets**

The term interconnection is used to describe interfaces that join Ontario to other (external) control areas.

Ontario has interconnections with Manitoba, Minnesota, Quebec, Michigan, and New York.

**Interconnection Definitions**

Interconnection definitions are shown in Section 3.1.

**Interconnection Limits**

Interconnection limits are shown in Section 3.2.

**Interconnection Characteristics**

All of Ontario's non-radial interconnections are under phase-shifter control, except for Niagara New York.

New phase shifters will be installed on the Ontario – Michigan interconnection by June 2001. The purpose of the new phase shifters is to control a loop flow or parallel path flow called Lake Erie Circulation (LEC). LEC occurs naturally through a combination of transmission system impedance with interconnection-wide load/generation dispatch; it is measured as an unscheduled flow across the points of interconnection with New York, at Niagara Falls, and with Michigan. Much of the time, LEC enters Ontario at the New York Niagara interconnection and exits Ontario at the Michigan interconnection. Power flows associated with this condition are often greater than 500 MW; on occasion they exceed 1,000 MW. LEC flows also appear on and aggravate the BLIP and QFW interfaces as they are in a direct series path. With the incorporation of the new

phase shifters it is expected that the incidence of constrained operation of QFW will be greatly reduced.

**The Ontario - Manitoba Interconnection**

The OMTE and OMTW limits are both 288 MW in summertime, 300 MW in wintertime and are constrained by stability and thermal limitations.

**The Ontario - Minnesota Interconnection**

The MPFN and MPFS limits are 100 and 150 MW respectively and are constrained by stability and thermal limitations.

**The Ontario - Michigan Interconnection**

The Michigan interconnection is constrained by thermal limitations and will be under phase shifter control by June 2001.

Before June 2001:

During winter months, the limits are 1600 MW for flows into Ontario and 2,400 MW for flows out of Ontario. In the summer, the limits are 1,500 MW for flows into Ontario and 2,350 MW for flows out of Ontario.

After June 2001:

During winter months, the limits are 1800 MW for flows into Ontario and 2,450 MW for flows out of Ontario. In the summer, the limits are 1,765 MW for flows into Ontario and 2,450 MW for flows out of Ontario.

**The Ontario - New York Niagara Interconnection**

The New York Niagara interconnection, in the winter, is limited to 1,750 MW for flows into Ontario and 2,050 MW for flows out of Ontario. In the summer, the limit is 1,450 MW for flows into Ontario and 1,950 MW for flows out of Ontario. The interconnection is constrained by thermal limitations in the winter and summer.

The QFW interface is in series with the NY Niagara interconnection. All flows entering Ontario on the NY Niagara interconnection will also appear on the QFW interface; this includes purchases and parallel path flows. Based on past experience and studies, the QFW interface always hits its limit before the limit is reached on the NY Niagara interconnection for flows entering Ontario; as a result, the capability of the NY Niagara interconnection is never fully utilized.

Typically, when QFW hits its limit of 1,800 MW under summer conditions, the flow across the NY Niagara interconnection is 1,100 MW (its limit is 1,450 MW). Similarly, when QFW hits its limit of 2,000 MW under winter conditions, flow across the NY Niagara interconnection is 1,300 MW (its limit is 1,750 MW).

**The Ontario - New York East Interconnection**

The limit on this interconnection is 400 MW for flows into or out of Ontario. The interconnection is constrained by thermal limitations and is under the control of phase shifters.

**The Ontario Northeast - Quebec Interconnection**

The Quebec North interconnection is thermally limited to 78 MW under winter conditions and 64 MW under summer conditions, for flows into Ontario from radial generation in Quebec. For flows out of Ontario, the limit is 80 MW and this is simply based on the maximum amount of radial load available to be supplied in Quebec.

**The Ontario East - Quebec Interconnection**

The Quebec South interconnection is limited to 1,330 MW for flows into Ontario due to stability limitations and available radial generation. For flows out of Ontario the limit is 450 MW and is due to stability and thermal limitations.

## 2.0 Definitions and Limits of Ontario's Interfaces

### 2.1 Definitions of Ontario's Interfaces

(\* signifies the measurement point)

**Buchanan Longwood Input (BLIP) Interface consists of the following circuits:**

|       |                                |
|-------|--------------------------------|
| B562L | Bruce A to Longwood* 500 kV    |
| B563L | Bruce B to Longwood* 500 kV    |
| N582L | Nanticoke to Longwood* 500 kV  |
| D4W   | Detweiler to Buchanan* 230 kV  |
| D5W   | Detweiler to Buchanan* 230 kV  |
| M31W  | Middleport to Buchanan* 230 kV |
| M32W  | Middleport to Buchanan* 230 kV |
| M33W  | Middleport to Buchanan* 230 kV |

**Negative Buchanan Longwood Input (NBLIP) Interface consists of the following circuits:**

|       |                                |
|-------|--------------------------------|
| B562L | Longwood* to Bruce A 500 kV    |
| B563L | Longwood* to Bruce B 500 kV    |
| N582L | Longwood* to Nanticoke 500 kV  |
| D4W   | Buchanan* to Detweiler 230 kV  |
| D5W   | Buchanan* to Detweiler 230 kV  |
| M31W  | Buchanan* to Middleport 230 kV |
| M32W  | Buchanan* to Middleport 230 kV |
| M33W  | Buchanan* to Middleport 230 kV |

**Queenston Flow West (QFW) Interface consists of the following circuits:**

|       |                                                             |
|-------|-------------------------------------------------------------|
| Q23BM | Beck2* to Burlington and Middleport (Neale Junction) 230 kV |
| Q25BM | Beck2* to Burlington and Middleport (Neale Junction) 230 kV |
| Q24HM | Beck2* to Hamilton and Middleport (Hannon Junction) 230 kV  |
| Q29HM | Beck2* to Hamilton and Middleport (Hannon Junction) 230 kV  |
| Q30M  | Beck 2 (Allanburg Junction*) to Middleport 230 kV           |

**Flow East To Toronto (FETT) Interface consists of the following circuits:**

|       |                                   |
|-------|-----------------------------------|
| B560V | Bruce A to Claireville* 500 kV    |
| M570V | Milton to Claireville* 500 kV     |
| M571V | Milton to Claireville* 500 kV     |
| V586M | Middleport to Claireville* 500 kV |
| R14T  | Trafalgar* to Richview 230 kV     |
| R17T  | Trafalgar* to Richview 230 kV     |
| R19T  | Trafalgar* to Richview 230 kV     |
| R21T  | Trafalgar* to Richview 230 kV     |
| E8V   | Orangeville to Essa* 230 kV       |
| E9V   | Orangeville to Essa* 230 kV       |

**Flow North (FN) and Interface consists of the following circuits:**

X503E      Essa\* to Hamner 500 kV  
X504E      Essa\* to Hamner 500 kV  
D5H        Des Joachims\* to Holden 230 kV

**Flow South (FS) Interface consists of the following circuits:**

X503E      Hamner to Essa\* 500 kV  
X504E      Hamner to Essa\* 500 kV  
D5H        Holden to Des Joachims\* 230 kV

**East-West Transfer West (EWTW) Interface consists of the following circuits:**

W21M      Wawa\* to Marathon 230 kV  
W22M      Wawa\* to Marathon 230 kV

**East-West Transfer East (EWTE) Interface consists of the following circuits:**

W21M      Marathon to Wawa\* 230 kV  
W22M      Marathon to Wawa\* 230 kV

**Claireville North (CLAN) Interface consists of the following circuits:**

E510V      Claireville\* to ESSA 500kV  
E511V      Claireville\* to ESSA 500kV  
B82V      Claireville\* to Brown Hill 230kV  
B83V      Claireville\* to Brown Hill 230kV

**Claireville South (CLAS) Interface consists of the following circuits:**

E510V      ESSA to Claireville\* 500kV  
E511V      ESSA to Claireville\* 500kV  
B82V      Brown Hill to Claireville\* 230kV  
B83V      Brown Hill to Claireville\* 230kV

**Flow Away from Bruce Complex (FABC) Interface consists of the following circuits:**

B560V      Bruce\* to Claireville 500kV  
B561M      Bruce\* to Milton 500kV  
B562L      Bruce\* to Longwood 500kV  
B563L      Bruce\* to Longwood 500kV  
B4V        Bruce\* to Orangeville 230kV  
B5V        Bruce\* to Orangeville 230kV  
B22D      Bruce\* to Detweiler 230kV  
B23D      Bruce\* to Detweiler 230kV  
B27S      Bruce\* to Owen Sound 230kV  
B28S      Bruce\* to Owen Sound 230kV

**Flow West Into Cherrywood (FWIC) Interface consists of the following circuits:**

B540C      Bowmanville to Cherrywood\* 500kV  
B541C      Bowmanville to Cherrywood\* 500kV  
B542C      Bowmanville to Cherrywood\* 500kV  
B543C      Bowmanville to Cherrywood\* 500kV  
P15C      Dobbin to Cherrywood\* 230kV  
C28C      Chat Falls to Cherrywood\* 230kV  
H24C      Havelock to Cherrywood\* 230kV

H26C            Havelock to Cherrywood\* 230kV  
M29C            Merivale to Cherrywood\* 230kV  
B23C            Belleville to Cherrywood\* 230kV

## 2.2 Limits of Ontario's Interfaces

The Ontario major interfaces base limits, for all elements in service are shown in the Table D2.1.

**Table D2.1 Ontario's Interface Base Limits**

| Interface | Operating Security Limits (MW) |
|-----------|--------------------------------|
| BLIP      | 3500                           |
| NBLIP     | 1500                           |
| QFW       | 1800 Summer, 2000 Winter       |
| FABC      | 5200, normally not limiting    |
| FETT      | 5700                           |
| CLAN      | 2000                           |
| CLAS      | 1000                           |
| FN        | 1900                           |
| FS        | 1400                           |
| E-W       | 325 East, 350 West             |

### 3.0 Definitions and Limits of Ontario's Interconnections

#### 3.1 Definitions of Ontario's Interconnections

##### **The Ontario – Manitoba Interconnection**

K21W Kenora 230 kV to Whiteshell 115 kV including combination voltage regulator and phase shifting transformer bank T7 at Whiteshell,

K22W Kenora 230 kV to Whiteshell 115 kV including combination voltage regulator and phase shifting transformer bank T8 at Whiteshell,

SK1 Rabbit Lake 115 kV to Seven Sisters 115 kV including an in-line voltage regulating transformer at Seven Sisters (radial operation only).

##### **Ontario Manitoba Transfer West (OMTW) consists of the following circuits:**

K21W Kenora\* 230 kV to Whiteshell 230 kV

K22W Kenora\* 230 kV to Whiteshell 230 kV

##### **Ontario Manitoba Transfer East (OMTE) consists of the following circuits:**

K21W Whiteshell 230 kV to Kenora\* 230 kV

K22W Whiteshell 230 kV to Kenora\* 230 kV

##### **The Ontario – Minnesota interconnection**

F3M Fort Frances 115 kV to International Falls 115 kV including two phase shifting transformers operated in series, T10 and T11, located at International Falls.

##### **Minnesota Power Flow North (MPFN) consists of the following circuit:**

F3M International Falls 115 kV to Fort Frances\* 115 kV

##### **Minnesota Power Flow South (MPFS) consists of the following circuit:**

F3M Fort Frances\* 115 kV to International Falls 115 kV

##### **The Ontario – Quebec North interconnection consists of the following circuits:**

D4Z Dymond\* to Rapide Des Iles 115 kV,

H4Z Holden\* to Kipawa 115 kV,

##### **The Ontario – Quebec South interconnection consists of the following circuits:**

X2Y Chenaux to Bryson 115 kV,

Q4C Chats Falls to Quoyon 230 kV,

P33C Chats Falls to Pagan 230 kV,

H9A Hawthorne to Maclaren 115 kV,

H2AR Hawthorne to Maclaren 115 kV,

B5D St. Isidore to Beauharnois 230 kV,

B31L St. Lawrence to Beauharnois 230 kV.

##### **The Ontario – Michigan Interconnection consists of the following circuits:**

Before June 2001:

B3N Scott\* 230 kV to Bunce Creek 120 kV, including in-line autotransformer.

L4D Lambton\* 230 kV to St. Clair 345 kV, including in-line autotransformer.

L51D            Lambton\* 230 kV to St. Clair 345 kV, including in-line autotransformer.  
J5D             Keith\* 230 kV to Waterman 230 kV, including in-line combination voltage  
regulator and phase shifter SR5.

After June 2001:

B3N            Scott\* 230 kV to Bunce Creek 120 kV, including in-line autotransformer and  
phase shifter.  
L4D            Lambton\* 230 kV to St. Clair 345 kV, including two autotransformers in parallel  
and phase shifter.  
L51D           Lambton\* 230 kV to St. Clair 345 kV, including in-line autotransformer and  
phase shifter.  
J5D             Keith\* 230 kV to Waterman 230 kV, including in-line combination voltage  
regulator and phase shifter SR5.

**The Ontario – New York Interconnection at Niagara consists of the following 60 Hz circuits to the New York Power Authority (NYPA), and Niagara Mohawk (NiaMo):**

BP76           Beck2 230 kV to Packard 230 kV (NiaMo), including in-line voltage regulating  
transformer R76,  
PA27           Beck2 230 kV to Niagara Moses 230 kV (NYPA), including in-line voltage  
regulating transformer R27,  
PA301          Beck2 230 kV to Niagara Moses 345 kV (NYPA), including in-line 230 to 345  
kV autotransformers T301,  
PA302          Beck2 230 kV to Niagara Moses 345 kV (NYPA), including in-line 230 to 345  
kV autotransformers T302,  
BL104          Beck1 115 kV to Lockport 115 kV (NiaMo),

and the following two 25 Hz circuits

BSC105       Beck1 115 kV to Harper 69 kV (NiaMo), including an in-line 115 to 69 kV  
transformer at Parks TS,  
BSH106       Beck G7 to Harper 69 kV (NiaMo).

**The Ontario – New York Interconnection at St. Lawrence consists of the following 60 Hz circuits to the New York Power Authority (NYPA):**

L33P           St. Lawrence 230 kV to FDR Moses 230 kV (NYPA) including in-line voltage  
regulating transformer R33 and in-line phase shifting transformer PS33,  
L34P           St. Lawrence 230 kV to FDR Moses 230 kV (NYPA) including in-line  
combination voltage regulator and phase shifting transformer PSR34.

## 3.2 Limits of Ontario's Interconnections

The Ontario interconnection base limits, for all elements in service are shown in the Table D3.1.

**Table D3.1 Ontario's Interconnection Limits**

| <b>Interconnection</b>     | <b>Limit (MW)<br/>Flows Out of Ontario MW</b> | <b>Limit (MW)<br/>Flows Into Ontario</b> |
|----------------------------|-----------------------------------------------|------------------------------------------|
| Manitoba – Winter*         | 300                                           | 300                                      |
| Manitoba – Summer*         | 288                                           | 288                                      |
| Minnesota                  | 150                                           | 100                                      |
| Quebec North – Winter*     | 80                                            | 78                                       |
| Quebec North – Summer*     | 80                                            | 64                                       |
| Quebec South               | 450                                           | 1,330                                    |
| New York East              | 400                                           | 400                                      |
| New York Niagara – Winter* | 2,050                                         | 1,750                                    |
| New York Niagara – Summer* | 1,950                                         | 1,450                                    |
| Michigan – Winter*         | 2,400 / 2,450**                               | 1,600 / 1,800**                          |
| Michigan – Summer*         | 2,350 / 2,450**                               | 1,500 / 1,765**                          |

\*Seasonal Limits are based on thermal ratings and 75% of pre-load. Summer Limits apply from May 1 to October 31 and are based on 0-4 km/hr wind speed and 30 Deg.C ambient temperature (except on ties with Michigan, which are based on 35 Deg.C). Winter Limits apply from November 1 to April 30 and are based on 0-4 km/hr wind speed and 10 Deg.C ambient temperature.

\*\* For the Ontario – Michigan Interconnection the displayed values are, respectively, before June 2001 and after June 2001 (the in service date of the phase shifters).

## 4.0 Plans – Hydro One

**Table D4.1 Committed Plans - Hydro One**

| Committed Plans                                           | Purpose                                                                                                                                                  | Description                                                                            | Projected In-service |
|-----------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------------------------------------|----------------------------------------------------------------------------------------|----------------------|
| Establish connection to Maclaren Industries               | Increase interconnection capacity to Hydro Quebec                                                                                                        | Provide 230 kV interconnection via D5A                                                 | Sep. 2000            |
| Install generation rejection scheme in the West System    | Mitigate some of the impact of full compliance to NPCC, MAPP and NERC (this project deals with respecting loss of double circuit as single contingency). | Reject Atikokan GS for the loss of A21L/A22L or M23L/M24L. (Improve TEM and LE limits) | Nov. 2000            |
| Install phase-shifters on the interconnection to Michigan | Control Lake Erie Circulation and increase import capability                                                                                             | 845 MVA unit on L51D and L4D; Reconnect T7 auto to L4D for parallel operation with T8  | Jun. 2001            |
| Install shunt capacitor bank at Chatham SS                | Increase load meeting capability for the Windsor area                                                                                                    | 230 kV Capacitor: 225 MVAR @ 249.4 kV                                                  | Jun. 2001            |
| Refurbish Chatham SS                                      | Replace end of life facilities                                                                                                                           | Replace 230 kV circuit breakers and associated equipment                               | Jul. 2001            |
| Refurbish St Lawrence TS                                  | Replace end of life facilities                                                                                                                           | Replace 230 kV circuit breakers and associated equipment                               | Jul. 2001            |
| Refurbish L1S 115 kV line section                         | Transmission line refurbishment                                                                                                                          | Refurbish Crystal Falls GS x Warren DS                                                 | Dec. 2000            |

## 5.0 Planned Transmission Outages

**Table D5.1 Transmission Outages Northwest Zone**

| Seq Id# | Element Description                      | Start     | Finish    | Outage Type | Recall Hours | Reduction in Limit                                         | Impact                                   |
|---------|------------------------------------------|-----------|-----------|-------------|--------------|------------------------------------------------------------|------------------------------------------|
| 12      | K3D Rabbit Lake x Vermilion Bay DS 115kV | 18-Sep-00 | 30-Nov-00 | Continuous  | 8            |                                                            |                                          |
| 13      | ST5 Seven Sisters x Transcona 115kV      | 19-Sep-00 | 13-Oct-00 | Continuous  | 8            |                                                            |                                          |
| 31      | ST6 Seven Sisters x Transcona 115kV      | 02-Oct-00 | 13-Oct-00 | Continuous  | 8            |                                                            |                                          |
| 74      | D26A Dryden x Mackenzie 230kV            | 23-Oct-00 | 02-Nov-00 | Continuous  | 1            | 250 MW OMTW;<br>225 MW TEM<br>(Transfer East of Mackenzie) | Not Limiting for expected flow direction |
| 95      | WT34 Whiteshell x Transcona 115kV        | 06-Nov-00 | 01-Dec-00 | Continuous  | 8            |                                                            |                                          |
| 96      | 907 Littlefork TS x SHAN 230kV           | 06-Nov-00 | 22-Nov-00 | Continuous  | None         |                                                            |                                          |
| 149     | Whiteshell T8 failed                     | 04-Jun-00 | 31-Dec-01 | Continuous  | None         |                                                            |                                          |

**Table D5.2 Transmission Outages Northeast Zone**

| Seq Id# | Element Description             | Start     | Finish    | Outage Type     | Recall Hours | Reduction in Limit                             | Impact                                |
|---------|---------------------------------|-----------|-----------|-----------------|--------------|------------------------------------------------|---------------------------------------|
| 11      | L1S Verner DS x Warren DS 115kV | 18-Sep-00 | 30-Nov-00 | Continuous      | None         | 5 MW D4Z or H4Z in Mode 2; 15 MW D4Z in Mode 3 |                                       |
| 28      | W2C Wawa x Chapleau MS 115kV    | 01-Oct-00 | 10-Oct-00 | Continuous      | 1            |                                                |                                       |
| 44      | L22L25 Martindale 230kV         | 02-Oct-00 | 11-Oct-00 | Continuous      | 8            |                                                |                                       |
| 57      | A24P Algoma x Mississagi 230kV  | 16-Oct-00 | 26-Oct-00 | Continuous      | None         |                                                |                                       |
| 75      | T28P Wells x Mississagi 230kV   | 23-Oct-00 | 27-Oct-00 | Continuous      | 12           |                                                |                                       |
| 97      | X27A Hanmer x Algoma 230kV      | 06-Nov-00 | 24-Nov-00 | Daily - PM only | 0.5          |                                                |                                       |
| 100     | T27P Wells x Mississagi 230kV   | 13-Nov-00 | 24-Nov-00 | Continuous      | 12           |                                                |                                       |
| 110     | P26W Mississagi x Wawa 230kV    | 27-Nov-00 | 08-Dec-00 | Continuous      | 12           | 105 MW EWTE                                    | May limit NW Zone Generation Dispatch |

**Table D5.3 Transmission Outages Essa Zone**

| Seq Id# | Element Description                | Start     | Finish    | Outage Type              | Recall Hours | Reduction in Limit | Impact |
|---------|------------------------------------|-----------|-----------|--------------------------|--------------|--------------------|--------|
| 3       | T5 Waubashene 230kV                | 05-Sep-00 | 20-Oct-00 | Continuous               | 48           |                    |        |
| 16      | T2 Muskoka 230kV                   | 25-Sep-00 | 06-Oct-00 | Continuous               | 8            |                    |        |
| 32      | S2S Meaford x Stayner 115kV        | 02-Oct-00 | 24-Nov-00 | Continuous – No Weekends | 4            |                    |        |
| 63      | D4M Des Joachims GS x Minden 230kV | 16-Oct-00 | 20-Oct-00 | Continuous               | 3            |                    |        |
| 64      | D4M Des Joachims GS x Minden 230kV | 16-Oct-00 | 20-Oct-00 | Continuous               | 8            |                    |        |

**Table D5.4 Transmission Outages Bruce Zone**

| <b>Seq<br/>Id#</b> | <b>Element Description</b> | <b>Start</b> | <b>Finish</b> | <b>Outage<br/>Type</b> | <b>Recall<br/>Hours</b> | <b>Reduction in Limit</b> | <b>Impact</b> |
|--------------------|----------------------------|--------------|---------------|------------------------|-------------------------|---------------------------|---------------|
| 33                 | T27 Bruce A 230kV          | 02-Oct-00    | 13-Oct-00     | Continuous             | 8                       |                           |               |
| 34                 | E BUS Bruce A 500kV        | 02-Oct-00    | 06-Oct-00     | Continuous             | 8                       |                           |               |
| 35                 | R27 Bruce A 28kV           | 02-Oct-00    | 13-Oct-00     | Continuous             | 8                       |                           |               |
| 58                 | T4L560 Bruce A 500kV       | 16-Oct-00    | 20-Oct-00     | Continuous             | 4                       |                           |               |
| 76                 | L560 BUS Bruce A 500kV     | 23-Oct-00    | 27-Oct-00     | Continuous             | 8                       |                           |               |
| 77                 | HT4 BUS Bruce A 500kV      | 23-Oct-00    | 27-Oct-00     | Continuous             | 8                       |                           |               |
| 90                 | T25 Bruce A 230kV          | 06-Nov-00    | 10-Nov-00     | Continuous             | 8                       |                           |               |
| 91                 | R25 Bruce A 28kV           | 06-Nov-00    | 10-Nov-00     | Continuous             | 8                       |                           |               |
| 92                 | L24T25 Bruce A 230kV       | 06-Nov-00    | 10-Nov-00     | Continuous             | 8                       |                           |               |

**Table D5.5 Transmission Outages West Zone**

| Seq Id# | Element Description            | Start     | Finish    | Outage Type         | Recall Hours | Reduction in Limit                                                          | Impact                                                          |
|---------|--------------------------------|-----------|-----------|---------------------|--------------|-----------------------------------------------------------------------------|-----------------------------------------------------------------|
| 5       | HL45 Buchanan 230kV            | 11-Sep-00 | 27-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 17      | KL1 Scott 115kV                | 25-Sep-00 | 03-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 18      | HL27 Scott 230kV               | 25-Sep-00 | 06-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 20      | KT1L7 Seaforth 115kV           | 25-Sep-00 | 06-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 29      | DL42 Longwood 230kV            | 01-Oct-00 | 07-Oct-00 | Continuous          | 1            |                                                                             |                                                                 |
| 30      | L23L29 Chatham 230kV           | 01-Oct-00 | 13-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 36      | L29 BUS Chatham 230kV          | 02-Oct-00 | 09-Oct-00 | Daily - No Weekends | 4            |                                                                             |                                                                 |
| 37      | PL6 Scott 115kV                | 02-Oct-00 | 12-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 45      | L5L37 Buchanan 230kV           | 06-Oct-00 | 19-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 46      | 1K2 Buchanan 115kV             | 06-Oct-00 | 13-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 47      | T4L5 Buchanan 115kV            | 09-Oct-00 | 20-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 52      | T3 Crawford 115kV              | 13-Oct-00 | 29-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 53      | J4C Keith TS x Crawford 115kV  | 14-Oct-00 | 18-Oct-00 | Continuous          | 8            |                                                                             |                                                                 |
| 54      | 1P2 Buchanan 115kV             | 14-Oct-00 | 20-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 55      | T4 Crawford 115kV              | 14-Oct-00 | 29-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 56      | KL29 Chatham 230kV             | 15-Oct-00 | 20-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 71      | HL37 Buchanan 230kV            | 21-Oct-00 | 03-Nov-00 | Continuous          | None         |                                                                             |                                                                 |
| 72      | L5K Buchanan 115kV             | 21-Oct-00 | 27-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 73      | DL21 Chatham 230kV             | 22-Oct-00 | 27-Oct-00 | Continuous          | None         |                                                                             |                                                                 |
| 81      | L9P Buchanan 115kV             | 28-Oct-00 | 03-Nov-00 | Continuous          | None         |                                                                             |                                                                 |
| 83      | L21L45 Chatham 230kV           | 29-Oct-00 | 03-Nov-00 | Continuous          | None         |                                                                             |                                                                 |
| 89      | KL45 Chatham 230kV             | 05-Nov-00 | 10-Nov-00 | Continuous          | None         |                                                                             |                                                                 |
| 98      | KL24 Chatham 230kV             | 12-Nov-00 | 17-Nov-00 | Continuous          | None         |                                                                             |                                                                 |
| 103     | DL28 Chatham 230kV             | 19-Nov-00 | 24-Nov-00 | Continuous          | None         |                                                                             |                                                                 |
| 104     | J5D Keith TS x Waterman 230kV  | 20-Nov-00 | 24-Nov-00 | Continuous          | 1            | 100 MW FABC; 500 MW Positive BLIP & Negative BLIP; 400 MW OH-MICH & MICH-OH | Reduced Interconnection Capacity                                |
| 109     | L24L28 Chatham 230kV           | 24-Nov-00 | 01-Dec-00 | Continuous          | None         |                                                                             |                                                                 |
| 111     | B563L Bruce B x Longwood 500kV | 27-Nov-00 | 15-Dec-00 | Daily               | 2            | 700 MW FABC; 500 MW Negative BLIP; 500 MW FETT                              | Negative BLIP will reduce the interconnection import capability |
| 112     | K BUS Chatham 230kV            | 27-Nov-00 | 01-Dec-00 | Continuous          | 4            |                                                                             |                                                                 |
| 117     | D BUS Chatham 230kV            | 04-Dec-00 | 08-Dec-00 | Continuous          | 4            |                                                                             |                                                                 |
| 140     | W37 Buchanan x Talbot 230kV    | 02-Apr-01 | 13-Apr-01 | Continuous          | 144          |                                                                             |                                                                 |
| 147     | W36 Buchanan x Talbot 230kV    | 16-Apr-01 | 27-Apr-01 | Continuous          | 144          |                                                                             |                                                                 |

**Table D5.6 Transmission Outages Niagara Zone**

| Seq Id# | Element Description                                 | Start     | Finish    | Outage Type              | Recall Hours | Reduction in Limit                        | Impact       |
|---------|-----------------------------------------------------|-----------|-----------|--------------------------|--------------|-------------------------------------------|--------------|
| 2       | C2P Crowland x Port Colborne TS 115kV               | 13-Aug-00 | 17-Dec-00 | Continuous               | None         |                                           |              |
| 6       | B3 Burlington x Dundas 115kV                        | 11-Sep-00 | 31-Oct-00 | Continuous               | 1            |                                           |              |
| 7       | HL7 Allanburg 115kV                                 | 11-Sep-00 | 05-Oct-00 | Continuous               | None         |                                           |              |
| 14      | Q30M Beck 2 x Middleport 230kV                      | 20-Sep-00 | 17-Nov-00 | Continuous – No Weekends | 2            | 100 MW FABC;<br>200 MW FETT<br>400 MW QFW | Not Limiting |
| 19      | D BUS Nanticoke 500kV                               | 25-Sep-00 | 05-Oct-00 | Continuous               | 1            |                                           |              |
| 38      | D1L29 Hamilton Beach 230kV                          | 02-Oct-00 | 06-Oct-00 | Continuous               | 24           |                                           |              |
| 48      | DL1 Allanburg 115kV                                 | 10-Oct-00 | 03-Nov-00 | Continuous               | None         |                                           |              |
| 59      | T8 Hamilton Beach 230kV                             | 16-Oct-00 | 20-Oct-00 | Continuous               | 8            |                                           |              |
| 60      | DL1 Allanburg 115kV                                 | 16-Oct-00 | 03-Nov-00 | Continuous               | None         |                                           |              |
| 61      | 1D2 Beck 2 230kV                                    | 16-Oct-00 | 27-Oct-00 | Continuous               | None         |                                           |              |
| 62      | H8 BUS Hamilton Beach 115kV                         | 16-Oct-00 | 20-Oct-00 | Continuous               | None         |                                           |              |
| 78      | B4 Burlington x Dundas 115kV                        | 23-Oct-00 | 27-Oct-00 | Continuous               | 4            |                                           |              |
| 84      | DK Newton 115kV                                     | 30-Oct-00 | 03-Nov-00 | Continuous               | 12           |                                           |              |
| 93      | A36N Allanburg x Niagara Murray 115kV               | 06-Nov-00 | 16-Nov-00 | Continuous               | None         |                                           |              |
| 102     | D6V Detweiler x Orangeville 230kV                   | 16-Nov-00 | 23-Nov-00 | Daily                    | 1            |                                           |              |
| 105     | T1 Hamilton Beach 230kV                             | 20-Nov-00 | 24-Nov-00 | Continuous               | 12           |                                           |              |
| 106     | A37N Allanburg x Niagara Murray 115kV               | 20-Nov-00 | 30-Nov-00 | Continuous               | None         |                                           |              |
| 113     | T7 Hamilton Beach 230kV                             | 27-Nov-00 | 01-Dec-00 | Continuous               | 12           |                                           |              |
| 118     | T6 Hamilton Beach 230kV                             | 04-Dec-00 | 08-Dec-00 | Continuous               | 12           |                                           |              |
| 122     | T5 Hamilton Beach 115kV                             | 11-Dec-00 | 15-Dec-00 | Continuous               | 12           |                                           |              |
| 125     | T8 Hamilton Beach 230kV                             | 18-Dec-00 | 22-Dec-00 | Continuous               | 12           |                                           |              |
| 128     | Q24HM Hamilton Beach x Dofasco Kenilworth CTS 230kV | 15-Jan-01 | 19-Jan-01 | Continuous               | None         |                                           |              |
| 130     | Q29HM Hamilton Beach x Dofasco Kenilworth CTS 230kV | 22-Jan-01 | 26-Jan-01 | Continuous               | None         |                                           |              |

**Table D5.7 Transmission Outages South Western Zone**

| Seq<br>Id# | Element Description | Start     | Finish    | Outage<br>Type | Recall<br>Hours | Reduction in Limit | Impact |
|------------|---------------------|-----------|-----------|----------------|-----------------|--------------------|--------|
| 65         | T11 Nanticoke 500kV | 16-Oct-00 | 27-Oct-00 | Continuous     | 96              |                    |        |

**Table D5.8 Transmission Outages Toronto Zone**

| Seq Id# | Element Description                             | Start     | Finish    | Outage Type              | Recall Hours | Reduction in Limit                                   | Impact                                                                                                                     |
|---------|-------------------------------------------------|-----------|-----------|--------------------------|--------------|------------------------------------------------------|----------------------------------------------------------------------------------------------------------------------------|
| 4       | DL511 Claireville 500kV                         | 05-Sep-00 | 27-Oct-00 | Continuous               | 96           |                                                      |                                                                                                                            |
| 8       | E511V Essa x Claireville 500kV                  | 11-Sep-00 | 03-Nov-00 | Daily                    | 4            | 700 MW CLAN; 1200 MW FN (Normal); 100 MW FS with G/R | Flow North may become limiting at off peak hours requiring Northern generation to be operated                              |
| 9       | T4 Malvern 230kV                                | 11-Sep-00 | 20-Oct-00 | Continuous               | 48           |                                                      |                                                                                                                            |
| 15      | R21T Richview x HANJ 230kV                      | 23-Sep-00 | 06-Oct-00 | Continuous               | 12           |                                                      |                                                                                                                            |
| 21      | T3 Ellesmere 230kV                              | 25-Sep-00 | 06-Oct-00 | Continuous               | 4            |                                                      |                                                                                                                            |
| 27      | R19T HANJ x Richview 230kV                      | 25-Sep-00 | 06-Oct-00 | Continuous               | 12           |                                                      |                                                                                                                            |
| 39      | H BUS Cecil 115kV                               | 02-Oct-00 | 06-Oct-00 | Continuous               | 8            |                                                      |                                                                                                                            |
| 40      | E511V Essa x Claireville 500kV                  | 02-Oct-00 | 06-Oct-00 | Continuous               | 12           |                                                      |                                                                                                                            |
| 41      | L7L8 Cecil 115kV                                | 02-Oct-00 | 27-Oct-00 | Continuous               | 48           |                                                      |                                                                                                                            |
| 49      | KL561 Milton 500kV                              | 10-Oct-00 | 17-Nov-00 | Continuous               | 6            | 400 MW FETT                                          | Not Limiting                                                                                                               |
| 66      | T23 Scarboro 230kV                              | 16-Oct-00 | 20-Oct-00 | Continuous               | 4            |                                                      |                                                                                                                            |
| 79      | L24CR Lakeview GS x Cooksville x Richview 230kV | 23-Oct-00 | 10-Nov-00 | Continuous - No Weekends | 2            |                                                      |                                                                                                                            |
| 80      | B560V Bruce A x Claireville 500kV               | 23-Oct-00 | 27-Oct-00 | Continuous               | 8            | 850 MW FABC; 500 MW Negative BLIP; 500 MW FETT       | Negative BLIP will reduce the interconnection import capability                                                            |
| 82      | T1 Markham MTS 1 230kV                          | 28-Oct-00 | 05-Nov-00 | Continuous               | None         |                                                      |                                                                                                                            |
| 85      | L5D Leaside x Duplex 115kV                      | 30-Oct-00 | 03-Nov-00 | Continuous               | 8            |                                                      | Some Toronto area outages may be impactful due to coincident Toronto Zone Generator Outages scheduled in Oct and early Nov |
| 86      | T16 Claireville 500kV                           | 30-Oct-00 | 03-Nov-00 | Continuous               | 8            | 150 MW FETT                                          | See above                                                                                                                  |
| 101     | T8P Pickering B 230kV                           | 13-Nov-00 | 17-Nov-00 | Continuous               | 4            |                                                      |                                                                                                                            |
| 107     | C4R Cherrywood x Malvern 230kV                  | 20-Nov-00 | 08-Dec-00 | Continuous               | 12           | 150 MW FETT                                          | Not Limiting                                                                                                               |
| 108     | C5R Cherrywood x Malvern 230kV                  | 20-Nov-00 | 08-Dec-00 | Continuous               | 12           | 150 MW FETT                                          | Not Limiting                                                                                                               |
| 114     | L540 BUS Cherrywood 500kV                       | 27-Nov-00 | 01-Dec-00 | Continuous               | 4            |                                                      |                                                                                                                            |
| 115     | B540C Bowmanville x Cherrywood 500kV            | 27-Nov-00 | 01-Dec-00 | Continuous               | 4            |                                                      |                                                                                                                            |
| 116     | T2 Carlton 115kV                                | 27-Nov-00 | 01-Dec-00 | Continuous               | None         |                                                      |                                                                                                                            |
| 119     | B541C Bowmanville x Cherrywood 500kV            | 04-Dec-00 | 08-Dec-00 | Continuous               | 4            |                                                      |                                                                                                                            |

(Table D5.8 continued)

| Seq Id# | Element Description                               | Start     | Finish    | Outage Type | Recall Hours | Reduction in Limit | Impact       |
|---------|---------------------------------------------------|-----------|-----------|-------------|--------------|--------------------|--------------|
| 120     | L541 BUS Cherrywood 500kV                         | 04-Dec-00 | 08-Dec-00 | Continuous  | 4            |                    |              |
| 121     | T3 Carlton 115kV                                  | 04-Dec-00 | 08-Dec-00 | Continuous  | None         |                    |              |
| 123     | C4R Malvern x LEAJ 230                            | 11-Dec-00 | 22-Dec-00 | Continuous  | 12           | 150 MW FETT        | Not Limiting |
| 124     | C5R Malvern x LEAJ 230                            | 11-Dec-00 | 22-Dec-00 | Continuous  | 12           | 150 MW FETT        | Not Limiting |
| 126     | H35D Hamilton Beach x Dofasco Bay Front CTS 230kV | 01-Jan-01 | 31-Jan-01 | Continuous  | None         |                    |              |

**Table D5.9 Transmission Outages East Zone**

| Seq Id# | Element Description                    | Start     | Finish    | Outage Type              | Recall Hours | Reduction in Limit                            | Impact                                                                                        |
|---------|----------------------------------------|-----------|-----------|--------------------------|--------------|-----------------------------------------------|-----------------------------------------------------------------------------------------------|
| 1       | T52 Lennox 500kV                       | 07-Mar-99 | 15-Mar-01 | FO                       | None         |                                               |                                                                                               |
| 22      | D6 PTAW x Chalk River CTS 115kV        | 25-Sep-00 | 06-Oct-00 | Continuous               | 4            |                                               |                                                                                               |
| 23      | W6MC Stewartville x Marchwood MS 115kV | 25-Sep-00 | 03-Nov-00 | Continuous - No Weekends | 4            | 140 MW Lower Madawaska Total                  | May bottle generation at local hydro plants unless coincident generator outages are scheduled |
| 24      | X522A Lennox x Hawthorne 500kV         | 25-Sep-00 | 06-Oct-00 | Continuous - No Weekends | 4            | 400 MW Flow Into Ottawa (FIO)                 | Not Limiting for Demand Levels in the Fall of Year 2000                                       |
| 25      | L22 BUS St Lawrence 230kV              | 25-Sep-00 | 05-Oct-00 | Continuous               | 6            |                                               |                                                                                               |
| 26      | AL22 St Lawrence 230kV                 | 25-Sep-00 | 15-Oct-00 | Continuous               | 144          |                                               |                                                                                               |
| 42      | L2L21 Hinchinbrooke 230kV              | 02-Oct-00 | 06-Oct-00 | Continuous               | 1            |                                               |                                                                                               |
| 43      | HL34 St Lawrence 230kV                 | 02-Oct-00 | 06-Oct-00 | Continuous               | 8            |                                               |                                                                                               |
| 50      | X6 Chenaux x Cobden TS 115kV           | 10-Oct-00 | 27-Oct-00 | Continuous               | 1            |                                               |                                                                                               |
| 51      | X523A Lennox x Hawthorne 500kV         | 10-Oct-00 | 27-Oct-00 | Continuous - No Weekends | 4            | 400 MW Flow Into Ottawa (FIO)                 | Not Limiting for Demand Levels in the Fall of Year 2000                                       |
| 67      | L22L27 Hinchinbrooke 230kV             | 16-Oct-00 | 20-Oct-00 | Continuous               | 1            |                                               |                                                                                               |
| 68      | HT5L31 Hawthorne 230kV                 | 16-Oct-00 | 20-Oct-00 | Continuous               | 4            |                                               |                                                                                               |
| 69      | M5G Merivale x Lisgar TS 115kV         | 16-Oct-00 | 26-Oct-00 | Continuous               | 24           |                                               |                                                                                               |
| 70      | HL26 St Lawrence 230kV                 | 16-Oct-00 | 12-Nov-00 | Continuous               | 144          |                                               |                                                                                               |
| 87      | L24A St Lawrence x Hawthorne 230kV     | 30-Oct-00 | 10-Nov-00 | Continuous - No Weekends | 4            | 100 MW FIO                                    | Not Limiting for Demand Levels in the Fall of Year 2000                                       |
| 88      | C27P Dobbin TS x BANN 230kV            | 30-Oct-00 | 03-Nov-00 | Continuous               | 12           | 240 MW Flow Into Dobbin (FID); 30 MW FIO      | Requires local generation support and/or Generator cross-tripping armed                       |
| 138     | G4 Darlington A 0kV                    | 30-Mar-01 | 15-Apr-01 | FO                       | 0.1          |                                               |                                                                                               |
| 94      | P4S Sidney TS x Port Hope 115kV        | 06-Nov-00 | 28-Dec-00 | Continuous - No Weekends | 4            | 75 MW FLOW Into Dobbin                        | Requires local generation support and/or Generator cross-tripping armed                       |
| 99      | L21L26 St Lawrence 230kV               | 12-Nov-00 | 08-Dec-00 | Continuous               | 144          |                                               |                                                                                               |
| 127     | L31L33 St Lawrence 230kV               | 02-Jan-01 | 26-Jan-01 | Continuous               | 144          |                                               |                                                                                               |
| 129     | B31L Beauharnois x St Lawrence 230kV   | 15-Jan-01 | 01-Feb-01 | Continuous – No Weekends | None         | 400 MW Beauharnois Delivery Limit; 100 MW FIO | Reduced import Capability from Hydro Quebec from 800 MW to 400 MW at Beauharnois              |
| 131     | L31 BUS St Lawrence 230kV              | 29-Jan-01 | 09-Feb-01 | Continuous               | 6            |                                               |                                                                                               |
| 132     | AL31 St Lawrence 230kV                 | 29-Jan-01 | 23-Feb-01 | Continuous               | 144          |                                               |                                                                                               |

(Table D5.9 continued)

| Seq<br>Id# | Element Description          | Start     | Finish    | Outage<br>Type | Recall<br>Hours | Reduction in Limit | Impact |
|------------|------------------------------|-----------|-----------|----------------|-----------------|--------------------|--------|
| 135        | L24 BUS St Lawrence<br>230kV | 26-Feb-01 | 09-Mar-01 | Continuous     | 6               |                    |        |
| 136        | L22L24 St Lawrence<br>230kV  | 26-Mar-01 | 19-Apr-01 | Continuous     | 6               |                    |        |
| 141        | KL520 Lennox 500kV           | 02-Apr-01 | 06-Apr-01 | Continuous     | 4               |                    |        |
| 142        | K BUS Lennox 500kV           | 02-Apr-01 | 06-Apr-01 | Continuous     | 4               |                    |        |
| 143        | T51 Lennox 500kV             | 02-Apr-01 | 06-Apr-01 | Continuous     | 4               |                    |        |
| 148        | H32L33 St Lawrence<br>230kV  | 23-Apr-01 | 17-May-01 | Continuous     | 6               |                    |        |