

Ontario Transmission System

JUNE 22, 2017

Caution and Disclaimer

The contents of these materials are for discussion and information purposes and are provided “as is” without representation or warranty of any kind, including without limitation, accuracy, completeness or fitness for any particular purpose. The Independent Electricity System Operator (IESO) assumes no responsibility for the consequences of any errors or omissions. The IESO may revise these materials at any time in its sole discretion without notice. Although every effort will be made by the IESO to update these materials to incorporate any such revisions it is up to you to ensure you are using the most recent version.

Table of Contents

Table of Contents	iii
List of Tables	iii
1.0 Introduction	1
2.0 Transmission Zones	2
2.1 Zone Characteristics	2
3.0 Transmission Interfaces	5
3.1 Interface Definitions	5
3.2 Interface Characteristics	5
3.3 Interface Capability Limits	7
4.0 Transmission Interconnections	14
4.1 Interconnection Definitions	14
4.2 Interconnection Characteristics	14
4.3 Interconnection Flow Limits	17

List of Tables

Table 3.3 Interface Limits with All Elements in-service.....	7
Table 4.3 Interconnection Flow Limits	18

List of Figures

Figure 2.1.1 Geographical Zones in Ontario's Power Transmission System	4
Figure 3.3.1 Ontario's Major Internal Transmission Interfaces.....	8
Figure 3.3.2 One Year Rolling (Apr. 2016 – Apr. 2017) Historical Flow Distribution - Interfaces.....	9
Figure 4.3.1 Ontario's Points of Interconnection with Neighbouring Areas.....	19
Figure 4.3.2 Ontario's Zones, Interfaces and Interconnections	20
Figure 4.3.3 One Year Rolling (Apr. 2016 – Apr. 2017) Historical Flow Distribution - Interconnections.....	21

1.0 Introduction

The Ontario Electricity Market Rules (Chapter 5) require that the Independent Electricity System Operator (IESO) provide forecasts and assessments of the reliability of the existing and committed resources and transmission facilities of the Ontario Market. These forecasts and assessments of the Ontario Electricity System are contained in the IESO 18-Month Outlook, which is released quarterly.

The Ontario Transmission System document is intended to complement the transmission assessments contained in the 18-Month Outlook by providing specific details on the Ontario transmission system, including the flow limits of major internal transmission interfaces and interconnections with neighbouring jurisdictions. Unless indicated otherwise, these limits are representative of both the present total transfer capabilities (TTC) as well as the anticipated TTCs during the time horizon of this Outlook with the assumption that all of the transmission elements are in-service.

This document is published twice a year in the second and fourth quarters, alongside the 18-Month Outlook, and is organized in three sections:

The first section discusses the geographical zones of the power transmission system in Ontario. The primary characteristics of each zone are summarized.

The second section discusses Ontario's major internal transmission interfaces. Limits of each interface are provided. The historical flow distribution on each interface during the previous twelve months is provided in graphical format.

The third section discusses Ontario's transmission interconnections with neighbouring jurisdictions. Limits of each interconnection are provided. The historical flow distribution on each interconnection during the previous twelve months is provided in graphical format.

Readers are invited to provide comments and/or suggestions on this document. To do so, please contact us at:

Toll Free: 1-888-448-7777

Tel: 905-403-6900

Fax: 905-403-6921

E-mail: customer.relations@ieso.ca.

- End of Section -

2.0 Transmission Zones

The Ontario transmission system is mainly comprised of a 500 kV transmission network, a 230 kV transmission network, and several 115 kV transmission networks. It is divided into ten zones whose characteristics are described in Section 2.1. Zonal boundaries have been chosen to correspond with the major interfaces described in Section 3.0. Figure 2.1.1 shows the geographical zones in Ontario's power transmission system.

2.1 Zone Characteristics

Bruce Zone

- The total resources are much greater than the zone peak demand.
- The generation is mostly nuclear with some wind.

East Zone

- The total resources exceed the zone peak demand.
- The generation is a mix of hydroelectric, oil, natural gas, some wind, and some solar.
- The zone is connected to the Québec grid via ties that are used to switch load or generation radially onto either system.
- The zone is also connected to the St. Lawrence interface with New York via phase angle regulator control.

Essa Zone

- The total resources are much less than the zone peak demand.
- The generation is mostly hydroelectric with some natural gas.
- For analytical purposes, Des Joachims generation and load, which is physically located in the East zone, has been modelled to be part of the Essa zone.

Niagara Zone

- The total resources are much higher than the zone peak demand.
- The generation is mostly hydroelectric with some natural gas.
- There is a free-flowing interconnection with New York.

Northeast Zone

- The total resources exceed the zone peak demand.
- The generation is mainly hydroelectric with some cogeneration, some wind, some solar, and some biofuel.
- Two 115 kV circuits connect radially to Québec.

Northwest Zone

- The total resources generally exceed the zone peak demand.
- The generation is mainly hydroelectric and biofuel with some wind and some natural gas.
- The zone is connected to the Manitoba and Minnesota systems.
- The 230 kV Manitoba interconnections and the Minnesota 115 kV interconnection are controlled by phase angle regulators. The Manitoba 115 kV interconnection is radial.

Ottawa Zone

- The total resources are much less than the zones peak demand.
- The generation is cogeneration.
- The interconnections with Québec consist of two 115 kV circuits and five 230 kV circuits. Two of the 230 kV circuits connect Ontario and Québec via bidirectional back-to-back HVDC converters located at Outaouais in Québec.

Southwest Zone

- The total resources are generally balanced with the zone peak demand.
- The generation is mostly wind and natural gas and some solar.


Toronto Zone

- The total resources are less than the zone peak demand.
- The generation is mostly nuclear with some natural gas.

West Zone

- The total resources generally exceed the zone peak demand.
- The generation is mostly natural gas and wind with some solar.
- The zone is connected to the Michigan system via two 230/345 kV circuits, one 230/115 kV circuit, and one 230 kV circuit. All four circuits have in-service phase angle regulators.

Figure 2.1.1 Geographical Zones in Ontario's Power Transmission System



- End of Section -

3.0 Transmission Interfaces

There are nine major internal interfaces in the Ontario transmission system. The characteristics of each interface are described in Section 3.2. Figure 3.3.1 provides a geographic depiction of Ontario's internal transmission zones and major transmission interfaces. Limits for these interfaces are also included in Figure 3.3.1 as well as in Table 3.3. The interface limits are used to ensure system stability, acceptable pre-contingency and post-contingency voltage levels, and acceptable thermal loading levels.

Detailed information on interface definitions and limits can be found in IESO System Control Orders (SCOs). The release of SCO limit related information to market participants will be considered by the IESO on a need to know and case by case basis. Requests for further information should be directed to the IESO Customer Relations.

3.1 Interface Definitions

Interfaces are defined by grouping one or more lines for the purpose of measuring their combined flow and enforcing a power flow limit or, as it is more commonly called, an interface limit. Interface limits are directional and interfaces may have limits imposed in one or both directions.

3.2 Interface Characteristics

The EWTE/EWTW Interface

The East-West Transfer East (EWTE) and East-West Transfer West (EWTW) flows are functionally related to the power flows between Ontario and Manitoba, and Ontario and Minnesota. In this relationship, the Ontario – Manitoba and Ontario – Minnesota flows can be generally thought of as the independent variables as they are under phase angle regulator control and can be adjusted to permit increased EWTE or EWTW flows.

The limits on the East-West tie are 325 MW to the east and 350 MW to the west. The EWTE and EWTW interfaces are constrained by voltage and stability limitations. A sample of the historical flow duration curve on the East-West Interface is shown in Figure 3.3.2.

The FN/FS Interface

The Flow South (FS) limit is 2,100 MW and the Flow North (FN) limit is 1,500 MW. The Flow North interface limit is a boundary condition since historical flows have never reached the limit of 1,900 MW. The Flow South interface limit is 2,100 MW and is limited by transient stability. A sample of the historical flow duration curve on the FN/FS interface is shown in Figure 3.3.2.

The P502X South Interface

The P502X South interface limit is 1,585 MW and is limited by transient stability. A sample of the historical flow duration curve on the P502X South interface is shown in Figure 3.3.2.

The CLAN/CLAS Interface

The Claireville North (CLAN) limit is 2,000 MW. The Claireville South (CLAS) interface has been determined to be non-limiting, and has been removed from Table 3.3. A sample of historical flow distribution on the CLAN interface is shown in Figure 3.3.2.

The FABCW Interface

Flow Away from Bruce Complex plus Wind (FABCW) is the sum of power that flows away from the Bruce Complex plus the power output from the wind farms near the Bruce zone. The limit depends on the number of Bruce units in service, the BLIP/NBLIP interface flow, the QFW interface flow, and other system parameters. The FABCW limit is required for preserving system and/or plant transient stability and to protect against post-contingency voltage collapse in Southwestern Ontario. Separate stability and voltage limits are defined for each recognized contingency. The FABCW interface limit is 7,500 MW based on the most restrictive contingency with all eight Bruce units in service. The unavailability of transmission elements and other system parameters such as reactive support provided from major generating stations and reactor switching may result in a lower limit.

A sample of historical flow distribution on the FABCW interface is shown in Figure 3.3.2.

The BLIP/NBLIP Interface

The Buchanan Longwood Input (BLIP) interface limit of 3,000 MW is constrained due to stability and voltage limitations. The Negative Buchanan Longwood Input (NBLIP) interface limit of 1,800 MW is typically constrained by voltage limitations. A sample of historical flow distribution on the BLIP interface is shown in Figure 3.3.2.

The QFW Interface

The Queenston Flow West (QFW) interface limit is approximately 1,990 MW for flows to the west in the winter. In the summer, the limit is approximately 1,600 MW to the west. There is no limit specified for flows to the east (towards New York), as the level of flows expected in that direction will not cause system concerns. A sample of historical flow distribution on the QFW interface is shown in Figure 3.3.2.

The FETT Interface

The Flow East Towards Toronto (FETT) interface limit was defined to prevent voltage collapse in the Toronto Area. Based on historical and expected flows, it was determined that the FETT interface is no longer limiting under normal conditions. As a result, the FETT interface limit becomes a boundary condition for which the other Southern Ontario limits are valid. The limit of this interface is 5,000 MW.

There is no limit specified for flows to the west, as the current level of flows expected in that direction is low. A sample of historical flow distribution on the FETT interface is shown in Figure 3.3.2.

The TEC Interface

The Transfer East from Cherrywood (TEC) interface does not have a predefined limit for up to any one single element out of service. The TEC interface is included to provide a boundary between the Toronto and East transmission zones. With these zones defined, specific studies can be conducted to consider the impact of varying resource dispatch scenarios on reliability.

The FIO Interface

With the addition of the new interconnection between Ontario and Québec, the Flow Into Ottawa (FIO) interface Limit is 2,900 MW to control pre-contingency and post-contingency voltage instability in the Ottawa zone. There is no limit specified on this interface for flows to the East zone. Under certain conditions, the FIO limit can be improved with the use of load rejection in the Ottawa zone. A sample of the historical flow distribution on the FIO interface is shown in Figure 3.3.2.

3.3 Interface Capability Limits

Table 3.3 summarizes the limits for the major interfaces in Ontario; normal system (all transmission elements in service) limits under normal conditions are shown.

Note that some limits are simple constants (e.g. BLIP, FETT) whereas others are more complicated and may depend on parameters such as the status of specific generator units, other transmission flows, Ontario demand, etc. (e.g. NBLIP, FABCW). In cases where interface limits are based on thermal capability, separate ratings are shown for summer and winter conditions.

Table 3.3 Interface Limits with All Elements In-service

Interface	Limit (MW)
BLIP	3,000
NBLIP	1,800
QFW	1,600 Summer, 1,990 Winter *
FABCW	7,500 **
FETT	5,000 ***
CLAN	2,000
FIO	2,900
FN	1,500 ***
FS	2,100
P502X South	1,585
EWTE	325
EWTW	350

Summer limits apply from May 1 to October 31. Winter limits apply from November 1 to April 30.

(*) QFW limit based on weather conditions.


(**) FABCW limit varies according to BLIP flow.

For each recognized contingency, separate voltage and stability limit ranges are defined.



Published limit range based on the most restrictive contingency under optimal Bruce System Conditions in SCO-South Tab1.

(***) Fixed boundary condition limit.


Figure 3.3.1 Ontario's Major Internal Transmission Interfaces

**Notes to Figure 3.3.1:**


1. Tables indicate interface limits with all transmission elements in service.
2. FABCW = FABC + MW output of wind farms near the Bruce zone

Figure 3.3.2 One Year Rolling (Apr. 2016 – Apr. 2017) Historical Flow Distribution - Interfaces


EWTW and EWTE Apr. 1, 2016 to Apr. 1, 2017




CLAN and CLAS Apr. 1, 2016 to Apr. 1, 2017




BLIP and NBLIP Apr. 1, 2016 to Apr. 1, 2017




QFW Apr. 1, 2016 to Apr. 1, 2017





FETT Apr. 1, 2016 to Apr. 1, 2017



FIO Apr. 1, 2016 to Apr. 1, 2017





- End of Section -

4.0 Transmission Interconnections

The term interconnection is used to describe interfaces that join Ontario to other jurisdictions (external control areas).

Ontario has interconnections with Manitoba, Minnesota, Québec, Michigan, and New York. The characteristics of each interconnection are described in Section 4.2. Figure 4.3.1 provides a geographic depiction of Ontario's internal transmission zones and transmission interconnection points with these jurisdictions. Operating security limits for these interconnections are also included in Figure 4.3.1 as well as in Table 4.3. Figure 4.3.2 summarizes the relationship between Ontario's zones, major internal interfaces and interconnections in a single diagram. The interconnection limits are used to ensure system and/or plant stability, acceptable pre-contingency and post-contingency voltage levels and/or acceptable thermal loading levels.

4.1 Interconnection Definitions

Like transmission interfaces, interconnection definitions are formed by grouping one or more lines for the purpose of measuring their combined flow and enforcing a power flow limit. Interconnections limits are defined for flows into Ontario (imports) and out of Ontario (exports).

4.2 Interconnection Characteristics

All of Ontario's synchronous interconnections are normally linked with phase angle regulators (PARs), except for the radial interconnections and the New York – Niagara interconnection. A sample of historical flow distribution on the Ontario interconnections is shown in Figure 4.3.3.

The Ontario – Manitoba Interconnection

The Ontario – Manitoba interconnection consists of two 230 kV circuits and one 115 kV circuit.

The transfers on the 230 kV interconnection defined as the Ontario – Manitoba Transfer are the Ontario – Manitoba Transfer East (OMTE) and the Ontario – Manitoba Transfer West (OMTW), and are constrained by stability and thermal limitations. The OMTW limits are 300 MW in the winter and 225 MW in the summer. The OMTE limits are 368 MW in the winter and 293 MW in the summer. The two summer limits were both reduced by 63 MW due to a temporary thermal rating reduction of equipment on the ties. These limits do not include the deadband margins associated with the phase angle regulator taps.

The flow on the 115 kV interconnection is limited to 68 MW for flows into Ontario in the winter and summer while no flow out of Ontario is allowed.

Ontario and Manitoba are synchronously connected at 230 kV, while the 115 kV interconnection is operated normally open.

The Ontario – Minnesota Interconnection

The Ontario – Minnesota interconnection consists of one 115 kV circuit. The transfers on this interconnection are the Minnesota Power Flow North (MPFN) and the Minnesota Power Flow South (MPFS).

The MPFN and MPFS limits are 100 MW and 150 MW respectively and are constrained by stability and thermal limitations. These limits do not include the deadband margins associated with the phase angle regulator taps. Ontario and Minnesota are synchronously connected.

The Ontario – Michigan Interconnection

The Ontario – Michigan interconnection consists of two 230/345 kV circuits, one 230/115 kV circuit, and one 230 kV circuit. The interconnection is constrained by thermal limitations.

Presently all four phase angle regulators are in service. The summer limit for flows both into Ontario and out of Ontario is 1,700 MW. The winter limit for flows both into Ontario and out of Ontario is 1,750 MW.

The Ontario – New York Niagara Interconnection

The Ontario – New York Niagara interconnection consists of two 230/345 kV circuits and two 230 kV circuits.

The winter and summer limits for flows out of Ontario are 1,800 MW and 1,650 MW respectively, while the winter and summer limits for flows into Ontario are 1,650 MW and 1,500 MW respectively.

The Queenston Flow West (QFW) interface is in series with the NY Niagara interconnection. All flows entering Ontario on the NY Niagara interconnection will also appear on the QFW interface; this includes imports and parallel path flows. Based on past experience and studies, the QFW interface would reach its limit before the limit is reached on the NY Niagara interconnection for flows entering Ontario; as a result, the capability of the NY Niagara interconnection could be constrained by thermal limitations in the QFW interface, which are dependent on weather conditions.

Ontario and New York Niagara are synchronously connected.

The Ontario – New York St. Lawrence Interconnection

The Ontario – New York St. Lawrence interconnection consists of two 230 kV circuits. The interconnection is constrained by thermal limitations and is under the control of phase angle regulators.

The limit on this interconnection is 300 MW for flows into Ontario and out of Ontario. The interconnection is constrained by thermal limitations in the winter and summer or NY limits.

Ontario and New York St. Lawrence are synchronously connected.

The Ontario – New York Total

The power transfers on the Niagara and St. Lawrence interconnections could be further limited by the New York scheduling limits on the Ontario – New York flowgate. When all transmission circuits are in service, the winter limits for flows into Ontario is 1,950 MW, and for flows out of Ontario is 2,100 MW. The summer limit for flows into Ontario is 1,800 MW, and for flows out of Ontario is 1,950 MW.

The Ontario – Québec North Interconnection

The Ontario – Québec North Interconnection consists of two radial 115 kV circuits (D4Z, H4Z) and is thermally limited.

For flows into Ontario from radial generation in Québec, the limit is 85 MW in the winter and 65 MW in the summer. For flows out of Ontario, the limit is 110 MW in the winter and 95 MW in the summer.

The Ontario – Québec South Interconnection

The Ontario – Québec South Interconnection consists of two 230 kV circuits in the East zone, five 230 kV circuits in the Ottawa zone, and two 115 kV circuits in the Ottawa zone. This includes the 230 kV interconnection from Hawthorne to the HVDC converters located at the Outaouais station in Québec.

The Québec South Interconnection limit for flows into Ontario are 2,665 MW in the summer and 2,665 MW in the winter, and are constrained by the transmission limitations and generation availability. For flows out of Ontario, due to stability and thermal limitations, the limits are 2,040 MW in the summer and 2,060 MW in the winter.

Due to the short circuit current limitations of the Hawthorne 115 kV breakers, H9A is not permitted to be connected at Masson and consequently cannot be used for importing or exporting until the breakers are replaced.

Parallel Path flows between Michigan & New York Niagara

Parallel path flows may occur between Michigan and New York Niagara, north of Lake Erie through Ontario, and south of Lake Erie through Pennsylvania due to a combination of transmission system impedance with interconnection-wide load/generation dispatch. As a result, the actual flows on the Michigan and New York Niagara interconnections may not equal the scheduled flows. For scheduled Ontario – Michigan power flows, part of the scheduled flows may flow on the NY Niagara interconnection due to parallel path flows. Likewise, for scheduled Ontario – New York power flows, part of the scheduled flows may flow on the Ontario – Michigan interconnection.

With full phase angle regulator control on the interties between Ontario and Michigan the inadvertent power flow across the interface is expected to be mitigated. When full PAR control of the Ontario – Michigan interconnection is utilized, parallel path flows of up to 600 MW in either direction are expected to be controlled. Control of parallel path flows should allow scheduled power flows to be maintained most of the time between Ontario, Michigan, and New York, and should also greatly reduce the incidence of constrained operation of the QFW interface.

Without full PAR control of the Ontario – Michigan interconnection, power flows across the Michigan interconnection are comprised of scheduled direct flows, scheduled New York Niagara parallel path flows, and LEC. Likewise, power flows across the New York Niagara interconnection are comprised of scheduled direct flows, scheduled Michigan parallel path flows, and LEC. This means that the total transfer from these two areas is usually limited to a flow that is less than the sum of the two interconnection flow limits.

Lake Erie Circulation (LEC) is a measure of the use of the Ontario transmission system by external parties in neighbouring jurisdictions. It is calculated using measured flows on the Michigan interconnection, measured flows on the New York interconnection, scheduled Michigan transactions, scheduled New York transactions, and measured internal generation located close to these interconnections. The flow can circulate through Ontario in a clockwise direction, in at Michigan and out at New York, or in counterclockwise direction, in at New York and out at Michigan. LEC flows also appear on the BLIP and QFW interfaces as they are in a direct series path.

Ontario Coincident Import/Export Capability

In the summer with all transmission elements in service the theoretical maximum capability for exports is up to 6,121 MW and for imports is up to 6,610 MW; in the winter the theoretical maximum capability for exports is 6,360 MW and for imports is 6,830 MW.

These values represent theoretical levels that could be achieved only with a substantial reduction in generation dispatch in the West and Niagara transmission zones. In practice, the generation dispatch required for high import levels would rarely, if ever, materialize. Therefore, at best, due to internal constraints in the Ontario transmission network in conjunction with external scheduling limitations, Ontario has an expected coincident import capability of approximately 5,200 MW.

Previous studies have shown that when full PAR control is available on the Ontario – Michigan interconnection, flow control of up to about 600 MW in either direction could be achieved. When circulation is limiting, this control will act to improve the coincident import/export capability.

4.3 Interconnection Flow Limits

Table 4.3 summarizes the flow limits for the interconnections; normal system (all transmission elements in service) limits are shown. In addition, emergency limits are shown when they differ from the normal system limits. All limits provided are total transfer capability (TTC) values with all transmission elements in-service.

For Michigan and New York, flow limits are given for summer and winter flows into and out of Ontario. With favourable conditions, the flow capabilities of the interconnections will not be affected by internal limitations in the transmission network. The amount of power that can be transferred may be lower than the table values under unfavourable dispatch and weather conditions. With unfavourable conditions, the flow capabilities may also be affected by internal limitations in the transmission network, in Ontario or in external areas.

When ambient weather conditions permit, flow limits over paths restricted by thermal considerations may be increased during real-time operation.

Table 4.3 Interconnection Flow Limits

Interconnection	Limit - Flows Out of Ontario (MW)	Limit - Flows Into Ontario (MW)
Manitoba – Summer*	225 ⁽³⁾	293 ^(3,5)
Manitoba – Winter*	300 ⁽³⁾	368 ^(3,5)
Minnesota	150	100 ⁽³⁾
Québec North (Northeast) – Summer*	95	65
D4Z	0 ⁽⁴⁾	65
H4Z	95 ⁽⁴⁾	0
Québec North (Northeast) – Winter*	110	85
D4Z	0	85
H4Z	110	0
Québec South (Ottawa) – Summer*	1,570	1,865
X2Y	0	65
Q4C	120	not of concern
P33C	0	300
D5A	200	250
H9A	0	0
HVDC	1,250	1,250
Québec South (Ottawa) – Winter*	1,590	1,865
X2Y	0	65
Q4C	140	not of concern
P33C	0	300
D5A	200	250
H9A	0	0
HVDC	1,250	1,250
Québec South (East) – Summer*	470	800
B31L + B5D	470	800
Québec South (East) – Winter*	470	800
B31L + B5D	470	800
New York St. Lawrence – Summer*	300	300
New York St. Lawrence – Winter*	300	300
New York Niagara – Summer*	1,650 ⁽¹⁾	1,500 ^(1,6)
Emergency Transfer Limit- Summer*	2,160 ⁽¹⁾	1,860 ^(1,6)
New York Niagara – Winter*	1,800 ⁽¹⁾	1,650 ^(1,6)
Emergency Transfer Limit- Winter*	2,200 ⁽¹⁾	2,200 ^(1,6)
Michigan – Summer*	1,700 ^(2,3)	1,700 ^(2,3)
Emergency Transfer Limit- Summer*	2,250 ^(2,3)	2,250 ^(2,3)
Michigan – Winter*	1,750 ^(2,3)	1,750 ^(2,3)
Emergency Transfer Limit- Winter*	2,350 ^(2,3)	2,350 ^(2,3)

* Summer Limits apply from May 1 to October 31. Winter Limits apply from November 1 to April 30.

(1) Flow limits depend on generation dispatch and demand outside Ontario.

(2) Normal limits are based on LTE ratings and Emergency limits are based on STE ratings.


(3) For real time operation of the interconnection, limits are based on ambient conditions.

(4) Limit based on 0 to 4 km/h wind speed and 30°C ambient temperature.

(5) Flows into Ontario include flows on circuit SK1.


(6) Flow limits into Ontario are shown without considering QFW transmission constraints within Ontario.

Figure 4.3.1 Ontario's Points of Interconnection with Neighbouring Areas







Notes to Figure 4.3.1:



1. Tables indicate flow limits for each interconnection. Note the Ontario coincident import/export capability is not necessarily the arithmetic sum of the individual flow limits.

Figure 4.3.2 Ontario's Zones, Interfaces and Interconnections**Notes to Figure 4.3.2:**

1. FABCW = FABC + MW Output of Wind Farms near Bruce Zone

Figure 4.3.3 One Year Rolling (Apr. 2016 – Apr. 2017) Historical Flow Distribution - Interconnections





- End of Document -

Independent Electricity System Operator

1600-120 Adelaide Street West

Toronto, Ontario M5H 1T1

Phone: 905.403.6900

Toll-free: 1.888.448.7777

E-mail: customer.relations@ieso.ca

ieso.ca

 [@IESO_Tweets](https://twitter.com/IESO_Tweets)

 facebook.com/OntarioIESO

 linkedin.com/company/ieso